

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Riley		Fraction NW 1/4 NW 1/4 NW 1/4		Section number 33	Township number T 10 S R 7 E/W	Range number 7
2. Distance and direction from nearest town or city: 5 m W.				3. Owner of well: John W. Bass		
Street address of well location if in city: OF MANHATTAN				R.R. or street: RFD 2		
				City, state, zip code: MANHATTAN, KS.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 2-23-76		
				Well depth 50 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC GL Weight 2.58 lbs./ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMPCO		
TOP SOIL		0	6	Type PVC Dia. 5"		
SANDY CLAY (BROWN)		6	24	Slot gouze .080 Length 5'		
FINE SAND		24	30	Set between 45 ft. and 50 ft.		
COURSE SAND		30	42	Gravel pack? <input checked="" type="checkbox"/> Size range of material YAYR		
COURSE GRAVEL		42	50	11. Static water level: 22 ft. below land surface Date 2-23-76		
				12. Pumping level below land surfaces: AIR TEST		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				Estimated maximum yield 50 g.p.m.		
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date ____		
				14. Well head completion: CAPPED		
				____ Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/>		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: 100 Direction E Type SEPTIC TANK		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name _____		
				Model number _____ HP _____ Volts _____		
				Length of drop pipe _____ ft. capacity _____ g.p.m.		
				Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks: OWNER WILL INSTALL SLAB		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
				Signed Strader Dohy Co Inc Date 2-24-76		
				Business name Strader Dohy Co Inc License No. 182		
				Address RT 1 HOLTON, KS		
				Authorized representative Walt Asher Date 2-24-76		

122-70-33
Sec
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5