

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County: <u>ROT. Aux. Topeka</u>	Township name: <u>Blue</u>	Fraction: <u>NE 1/4 - NE 1/4 - SE 1/4</u>	Section number: <u>810</u>	Town number: <u>10</u>	Range number: <u>8</u>
Distance and direction from nearest town or city:				3 Owner of well: <u>RAY Stephenson</u>		
Street address of well location if in city:				Address: <u>RR 1 S T. Geo, Kansas</u>		
Locate with "X" in section below:				Sketch map:		
2		Type and color of material	From	To	4 Well depth: <u>50</u> ft. Date of completion <u>7-8-75</u> Well diameter <u>10</u> in.	
		<u>Top Soil</u>	<u>0</u>	<u>6</u>	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		<u>Brown Clay</u>	<u>6</u>	<u>38</u>	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
		<u>Fine sand - COARSE SAND</u>	<u>38</u>	<u>41</u>	7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. Diam. _____ Weight <u>233</u> lbs./ft. <u>5</u> in. to <u>50</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ____ in. to ____ ft. depth	
		<u>COARSE SAND - Pea GRAVEL</u>	<u>41</u>	<u>50</u>	8 Screen: Manufacturer <u>Pump Co</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauge <u>.025</u> Length <u>7'</u> Set between <u>43</u> ft. and <u>50</u> ft. Fittings: _____ # <u>2</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____	
					9 Static water level: <u>NOT Measured</u> <u>28</u> ft. below land surface Date <u>7-8-75</u>	
					10 Pumping level below land surfaces: <u>AIR TEST</u> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>3.0</u> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: <u>Capped</u> <input type="checkbox"/> Pitless adapter <u>24</u> <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>N/E</u> Type <u>S/Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation		17 Water well contractor's certification:				
<u>1010</u> <u>Owner To Install slab</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		<u>STRADER DRILLING CO INC 182</u> Business name License No. _____ Address <u>PO Box 1 Holton KS 66436</u> Signed <u>Dale Baker</u> Date <u>7-13-75</u> Authorized representative				

10 SE 8E 3- C NE SE