

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County POTTAWATOMIE	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 11	Township number T 10 S R 8 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: RAY STEPHENSON <input checked="" type="checkbox"/> R. or street: R. R. ST. George, KS City, state, zip code: MANHATTAN, MO 66535			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 8-10-76 Well depth 45 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
TOP SOIL				0	6	9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 45 ft. depth, Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth, gage No. Z174
BROWN CLAY				6	32	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 Slot/gauze .020 Length 7 Set between 38 ft. and 45 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material .030 X .060
COURSE SAND-MEDIUM GR.				32	45	11. Static water level: <input type="checkbox"/> mo./day/yr. 26 ft. below land surface Date 8-10-76
						12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
						16. Nearest source of possible contamination: ft. 150 Direction SE Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		OWNER WILL INSTALL LAB		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER Debg. Co Inc 182 Business name _____ License No. _____ Address RT1 Holton, KS Signed Dale Peterson Date 8-14-76 Authorized representative		

T 10 S R 8 E W
1/4 1/4 1/4 1/4
SE SE SE SE SE SE SE SE SE SE