

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Riley	Fraction SE 1/4 - SE 1/4 --- NW 1/4 SW 1/4 NE 1/4 NE 1/4	Section number 25	Township number T 10 S R 8 E/W	Range number 8
2. Distance and direction from nearest town or city: 6 1/2 mi. east of Manhattan, Ks. of K-18 & 1/2 mi. south. Street address of well location if in city:			3. Owner of well: John G. Holle R.R. or street: R. R. #3 City, state, zip code: Manhattan, Ks. 66502		
4. Locate with "X" in section below:		Sketch map: K-18		6. Bore hole dia. 30 in. Completion date 8-30-77 Well depth 74 ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material steel Height: (Above) or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 54 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .029	
				10. Screen: Manufacturer's name Free-Flo W. A. Brown Enterprises Type steel Dia. 16" (Slot) gauze 1/4x4 Length 20' Set between 54 ft. and 74 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/8x1/4"	
				11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 6-18-77	
				12. Pumping level below land surfaces: 56 ft. after 1 hrs. pumping 600 g.p.m. 65 ft. after 3 hrs. pumping 740 g.p.m. Estimated maximum yield 750 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: drainage ft. 70 Direction east Type ditch Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name _____ License No. _____ Address St. Marys, Ks. 66536 Signed W. A. Holle Date 9-27-77 Authorized representative	
18. Elevation:	19. Remarks: We do not install pumps. Delay in filing report due to delay in obtaining legal description.				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T
R
W
S
E
1/4
1/4
1/4
1/4