

49



USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

far E. 1/2 section SESE NW

1 Location of well:	County <b>Riley</b>	Township name <b>Manhattan</b>	Fraction <b>TRACT.</b>	Section number <b>30</b>	Town number <b>10</b>	Range number <b>8 E</b>
Distance and direction from nearest town or city: <b>1 1/2 S. Manhattan KS.</b>			3 Owner of well: <b>L. Skulley</b>			
Street address of well location if in city:			Address: <b>RR 2 Manhattan, KS</b>			
Locate with "X" in section below: N  W S E 1 Mile		Sketch map: 		4 Well depth: <b>45</b> ft. Date of completion <b>5-2-75</b> Well diameter <b>12</b> in.		
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
						7 Casing: Material <b>PK</b> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>24</b> in. Diam. <b>6</b> in. Weight <b>2.33</b> lbs./ft. <b>6</b> in. to <b>45</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth
Top Soil		0		5		8 Screen: Manufacturer <b>Pumpco</b> Type <b>PUC</b> Dia. <b>6</b> Slot <b>0.025</b> Length <b>6'</b> Set between <b>39</b> ft. and <b>45</b> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>#3</b>
Yellow Clay		5		30		9 Static water level: <b>NOT MEASURED</b> — ft. below land surface Date —
Coarse Sand - Small gravel		30		45		10 Pumping level below land surfaces: <b>AIR TEST</b> — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield <b>100</b> g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —
						12 Well head completion: <b>CAPPED</b> <input type="checkbox"/> Pitless adapter <b>24</b> inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.
						14 Nearest source of possible contamination: ft. <b>150</b> Direction <b>WEST</b> Type <b>S-T</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation <b>1020</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Strader Drilling Co. Inc. 182</b> Business name — License No. — Address <b>91-75N. Holton KANS.</b> Signed <b>Dale Nelson</b> Date <b>5-8-75</b> Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5