


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Riley	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 30	Township number T 10 S 8 R 8 E	Range number
2. Distance and direction from nearest town or city: 1 S OF			3. Owner of well: TENNYSON COLLINS			
Street address of well location if in city: MANHATTAN			R.R. or street: 1317 COLLINS LANE			
City, state, zip code: MANHATTAN, KS 66502						
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 in. Completion date 8-15-78		
				Well depth 39 ft.		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
TOP SOIL		0	7	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
FINE SAND		7	18	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
FINE SAND - COARSE SAND		18	39	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: 29 in. above or below		
				Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in.		
				RMP PVC 9L Weight 2.50 lbs./ft.		
				Dia. 5 in. to 39 ft. depth Wall Thickness: inches or		
				Dia. 5 in. to 39 ft. depth gauge No. 1279		
				10. Screen: Manufacturer's name PUMPEO MRE		
				Type PVC Dia. 5		
				Slot/gauze .020 Length 10		
				Set between 29 ft. and 39 ft.		
				Gravel pack? <input checked="" type="checkbox"/> Size range of material 1030x1060		
				11. Static water level: 18 ft. below land surface Date 9-15-78		
				12. Pumping level below land surfaces:		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				Estimated maximum yield 20 g.p.m.		
				13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____		
				14. Well head completion: CAP		
				____ Pitless adapter 29 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/>		
				With: ____ Neat cement ____ Bentonite ____ Concrete		
				Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination:		
				ft. 200 Direction S Type SEPTIC		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
				17. Pump: Not installed		
				Manufacturer's name ____		
				Model number ____ HP ____ Volts ____		
				Length of drop pipe ____ ft. capacity ____ g.p.m.		
				Type: ____ Submersible ____ Turbine		
				____ Jet ____ Reciprocating		
				____ Centrifugal ____ Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		OWNER TO INSTALL SLAB		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
				STRADER DELG CO License No. 182		
				Business name RTI HOLTON, KS		
				Address 1000 Ashmun Date 8-17-78		
				Signed Walter Ashmun Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5