

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County POTTAWATOMIE Reley	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 4	Township number T 10 S	Range number R 9 E/W
2. Distance and direction from nearest town or city: 5 E. 5 S Street address of well location if in city: OF MANHATTAN			3. Owner of well: EVERETT LUNDQUIST R.R. or street: ARI ST. GEORGE City, state, zip code:			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 12 in. Completion date 7-20-76 Well depth 110 ft.	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
TOP SOIL			0	5	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP PVC 9L Weight 2.53 lbs./ft. Dia. 5 in. to 110 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 2.74	
SANDY CLAY (BROWN)			5	60	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 Slot/gauze .020 Length 10 Set between 94 ft. and 104 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/8	
FINE SAND - COURSE SAND			60	110	11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 7-20-76	
Blue shale			110		12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
					14. Well head completion: CAP Pitless adapter 24 Inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.	
					16. Nearest source of possible contamination: ft. 150 Direction NW Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: OWNER WILL INSTALL SLAB			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					Business name Stander Dely Co Inc License No. 182 Address ARI HOLLOW, KS Signed Dale Rubin Date 7-25-76 Authorized representative	