

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County POTAWATOMIE	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 6	Township number T 10 S R 9 E 1/4	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:	2.5 W IN OF ST. GEORGE		3. Owner of well: Steve Torrey R.R. or street: 103 BERTRAND City, state, zip code: ST. MARY'S, KS 66536		
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 12 in. Completion date _____ Well depth 140 ft. 9-25-78		
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material	From	To	9. Casing: Material PVC Height: Above of below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP _____ PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1279		
TOP SOIL	0	6	10. Screen: Manufacturer's name PUMPCO MPE Type PVC Dia. 5 Slot/gauze 1020 Length 10 Set between 128 ft. and 138 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 20x40		
SANDY SILT	6	80	11. Static water level: _____ mo./day/yr. 95 ft. below land surface Date 9-25-78		
FINE SAND	80	140	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ 40 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
			16. Nearest source of possible contamination: ft. 200 Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	OWNER TO INSTALL SLAB		5 TRADER DOLG CO 182 Business name License No. _____ Address RT 1 Holton, KS Signed Dale Ciskin Date 9-27-78 Authorized representative		