

For Rep

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Pottawatomie Fraction SW 1/4 NW 1/4 NW 1/4 Section number 10 Township number T 10 S R 9 E W Range number									
2. Distance and direction from nearest town or city: 1 N 1 E Street address of well location if in city: ST. GEO, KS									
3. Owner of well: ALVIN VIRGIN R.R. or street: 517 N. JULIETTE City, state, zip code: MANHATTAN, KANSAS 66502									
4. Locate with "X" in section below: 	6. Bore hole dia. 12 in. Completion date 12-16-77 Well depth 98 ft.								
	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary								
5. Type and color of material	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other								
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Tan Silty Sand</td> <td>0 58</td> </tr> <tr> <td>Brown Fine Sand</td> <td>58 68</td> </tr> <tr> <td>Gray Shale & Limestone</td> <td>68 100</td> </tr> </tbody> </table>	From	To	Tan Silty Sand	0 58	Brown Fine Sand	58 68	Gray Shale & Limestone	68 100	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP PVC Blue Weight 2.74 lbs./ft. Dia. 5 in. to 98 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1208
From	To								
Tan Silty Sand	0 58								
Brown Fine Sand	58 68								
Gray Shale & Limestone	68 100								
	10. Screen: Manufacturer's name Pumped Type PVC Dia. 5" Slot/gauze 020 Length 10' Set between 58 ft. and 68 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 030								
	11. Static water level: <input type="checkbox"/> mo./day/yr. 50 ft. below land surface Date 12-16-77								
	12. Pumping level below land surfaces: Nil Test <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 25 g.p.m.								
	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date								
	14. Well head completion: Top Cap <input type="checkbox"/> Pitless adapter 24 inches above grade								
	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.								
	16. Nearest source of possible contamination: #17 Note ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No								
	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other								
18. Elevation:	19. Remarks: Owner to pour slab 16. New Proposed Home site								
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRAIDER DRIG. Co. Inc 182 Business name License No. Address RT 1 HOLTON, KS Signed Dale Ashm Date 12-22-77 Authorized representative								

10-9-77
10 Sec NW 1/4