

WATER WELL RECORD

Form WWC-5

Division of Water Resources; App. No.

48193

1 LOCATION OF WATER WELL:
 County: POTAWATOMIE Fraction NW 1/4 SE 1/4 NE 1/4 Section Number 23 Township Number T 10 S 23 Range Number R 9 Q/W
 Distance and direction from nearest town or city street address of well if located within city? **Global Positioning Systems** (decimal degrees, min. of 4 digits)
 Latitude: N 39° 10' 6"
 Longitude: W 96° 22' 26"
 Elevation: _____ Datum: _____ Data Collection Method: _____

2 WATER WELL OWNER: Tam Ebert
 RR#, St. Address, Box # : 11650 Louisville Rd
 City, State, ZIP Code : St George KS 66535

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

N

NW	NE
SW	SE

S

4 DEPTH OF COMPLETED WELL 63 ft.

Depth(s) Groundwater Encountered (1).....12..... ft. (2)..... ft. (3)..... ft.
 WELL'S STATIC WATER LEVEL.....11..... ft. below land surface measured on mo/day/yr.....
 Pump test data: Well water was.....ft. after..... hours pumping..... gpm
 Est. Yield.....gpm: Well water was.....ft. after..... hours pumping..... gpm
 WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well
 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 Irrigation 4 Industrial 7 Domestic (lawn & garden) 10 Monitoring well

Was a chemical/bacteriological sample submitted to Department? Yes No ; If yes, mo/day/yrs
 Sample was submitted..... Water well disinfected? Yes No

5 TYPE OF CASING USED: 5 Wrought Iron 8 Concrete tile CASING JOINTS: Glued Clamped.....
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded.....
 PVC 4 ABS 7 Fiberglass Threaded.....
 Blank casing diameter 1.6" in. to 4.3 ft., Diameter in. to ft., Diameter in. to ft.
 Casing height above land surface..... 2 FT in., Weight lbs./ft. Wall thickness or guage No. DR 26

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless Steel 5 Fiberglass 7 PVC 9 ABS 11 Other (Specify) PVC 26
 2 Brass 4 Galvanized Steel 6 Concrete tile 8 RM (SR) 10 Asbestos-Cement 12 None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 7 Torch cut 9 Drilled holes 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped Saw cut 10 Other (specify)

SCREEN-PERFORATED INTERVALS: From 4.3 ft. to 6.3 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.

GRAVEL PACK INTERVALS: From 2.0 ft. to 6.3 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.

6 GROUT MATERIAL: 1 Neat cement Cement grout 3 Bentonite 4 Other

Grout Intervals: From 0 ft. to 2.0 ft., From ft. to ft., From ft. to ft.

What is the nearest source of possible contamination:
 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 13 Insecticide storage 16 Other (specify below)
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 14 Abandoned water well
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 15 Oil well/gas well

Direction from well? none How many feet?

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	1	sandy soil			
1	6.3	medium to coarse sand			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) Apr 18 13 and this record is true to the best of my knowledge and belief.
 Kansas Water Well Contractor's License No. B 21 This Water Well Record was completed on (mo/day/year) May 9 13 under the business name of BERRY SISK DRILLING CO by (signature) Ray Sisk 816-577-4531

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well. Visit us at <http://www.kdheks.gov/waterwell/index.html>.



KANSAS DEPARTMENT OF AGRICULTURE
Dale A. Rodman, Secretary of Agriculture

DIVISION OF WATER RESOURCES
David W. Barfield, Chief Engineer

**APPROVAL OF APPLICATION
and
PERMIT TO PROCEED**

(This Is Not a Certificate of Appropriation)

This is to certify that I have examined Application, **File No. 48,193** of the applicant

**Thomas L. Ebert
11650 Louisville Rd
St. George, Kansas 66535**

for a permit to appropriate water for beneficial use, together with the maps, plans and other submitted data, and that the application is hereby approved and the applicant is hereby authorized, subject to vested rights and prior appropriations, to proceed with the construction of the proposed diversion works (except those dams and stream obstructions regulated by K.S.A. 82a-301 through 305a, as amended), and to proceed with all steps necessary for the application of the water to the approved and proposed beneficial use and otherwise perfect the proposed appropriation subject to the following terms, conditions and limitations:

1. That the priority date assigned to such application is **June 27, 2012**.

2. That the water sought to be appropriated shall be used for irrigation use on land described in application, as follows:

- 1.0 acres in the Northeast Quarter of the Northeast Quarter (NE $\frac{1}{4}$ NE $\frac{1}{4}$),
- 11.0 acres in Lot 6,
- 19.0 acres in Lot 7,
- 12.5 acres in the Southeast Quarter of the Northeast Quarter (SE $\frac{1}{4}$ NE $\frac{1}{4}$),
- 4.0 acres in the Northeast Quarter of the Southeast Quarter (NE $\frac{1}{4}$ SE $\frac{1}{4}$),
- 1.5 acres in the Northwest Quarter of the Southeast Quarter (NW $\frac{1}{4}$ SE $\frac{1}{4}$),

a total of 49 acres in Section 23, Township 10 South, Range 9 East, Pottawatomie County, Kansas.

3. That the authorized source from which the appropriation shall be made is groundwater from the alluvial aquifer, to be withdrawn by means of one (1) well located in the Northwest Quarter of the Southeast Quarter of the Northeast Quarter (NW $\frac{1}{4}$ SE $\frac{1}{4}$ NE $\frac{1}{4}$) of Section 23, more particularly described as being near a point 3,505 feet North and 1,005 feet West of the Southeast corner of said section, in Township 10 South, Range 9 East, Pottawatomie County, Kansas, located substantially as shown on the topographic map accompanying the application.

4. That the appropriation sought shall be limited to a maximum diversion rate not in excess of **1,000 gallons per minute (2.23 c.f.s.)** and to a quantity not to exceed **53.9 acre-feet** of water for any calendar year.

