

CORRECTION(S) TO WATER WELL RECORD (WWC-5)

(to rectify lacking or incorrect information)

County: Pottawatomie

Location listed as:

Section-Township-Range: 9-10S-9E

Fraction (  $\frac{1}{4}$   $\frac{1}{4}$   $\frac{1}{4}$ ): NW NW NW

Location changed to:

10-10S-9E

NW NW NE

Other changes: Initial statements: \_\_\_\_\_

Changed to: \_\_\_\_\_

Comments: \_\_\_\_\_

verification method: Written & legal descriptions, county ownership map,  
aerial photos on KGS website, and Wamego & St. George  
1:24,000 topo. maps. initials: BRD date: 10/27/2005

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726

to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

66

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County POTAWATOMIE Fraction SW NW 1/4 NW 1/4 NW 1/4 Section number 10 Township number T-9-10 Range number 9E E/W

2. Distance and direction from nearest town or city: 6W - 2S Street address of well location if in city: OF WAMEGE 3. Owner of well: ELBERT SPAIN R.R. or street: City, state, zip code: ST. BECKE

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 8 in. Completion date 5-11-75 Well depth 100 ft.

7.  Cable tool  Rotary  Driven  Dug  Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  Irrigation  Air conditioning  Stock  Lawn  Oil field water  Other

9. Casing: Material QUC Height: Above or below Threaded  Welded  Surface 24 in. RMP PVC G/L Weight 2.33 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 214

10. Screen: Manufacturer's name Pumpco Type QUC Dia. 5  Slot/gauze .080 Length 20 Set between 40 ft. and 60 ft. and ft. Gravel pack? yes Size range of material 1/4" to 1/2"

5. Type and color of material	From	To
<u>TOP SOIL</u>	<u>0</u>	<u>6</u>
<u>FINE SAND</u>	<u>6</u>	<u>28</u>
<u>Blue shale</u>	<u>28</u>	<u>53</u>
<u>SANDSTONE</u>	<u>53</u>	<u>55</u>
<u>Grey Lime</u>	<u>55</u>	<u>73</u>
<u>Grey Shale</u>	<u>73</u>	<u>100</u>

11. Static water level: 50 ft. below land surface Date 5-11-75 mo./day/yr.

12. Pumping level below land surfaces: AIR TEST ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 7 g.p.m.

13. Water sample submitted:  Yes  No Date

14. Well head completion: CAPPED Pitless adapter 24 inches above grade

15. Well grouted? yes With:  Neat cement  Bentonite  Concrete Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: 150 ft. Direction E Type SEPTIC TANK Well disinfected upon completion?  Yes  No

17. Pump:  Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type:  Submersible  Turbine  Jet  Reciprocating  Centrifugal  Other

18. Elevation: 1140 Topography:  Hill  Slope  Upland  Valley

19. Remarks: Elbert J. Spain  
will install slab

20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name License No. Address Signed Strada Authorized representative Date

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

10-20-75  
R  
W  
11  
Sec  
1/4  
1/4  
1/4  
SW