

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: POT		County: POT	Fraction: NW 1/4 NE 1/4 NE 1/4	Section number: 14	Township number: T 10 S R 9	Range number: EW
2. Distance and direction from nearest town or city: 3 3/4 SW of				3. Owner of well: Robert L. Shaw		
Street address of well location if in city: Wamego on old US 24				R.R. or street: Wamego, Kansas 66547		
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 5 in. Completion date 6/9/76		
				Well depth 54 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PLASTIC Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 54 ft. depth <input checked="" type="checkbox"/> Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> gage No. <input type="checkbox"/>		
				10. Screen: Manufacturer's name J+L		
				Type PLASTIC Dia. 5" Slot/gauze 1/8" Length 10' Set between 44 ft. and 54 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/4" - 1/2"		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 19 ft. below land surface Date 6/9/76		
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 100 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? see remarks With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From ____ ft. to ____ ft.		
				16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation: ____		
19. Remarks: Customer knows regulations and will cement well himself.				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. See Cert Log on p. 258 Business name Clifton Kansas License No. ____ Address Clifton Kansas Signed Francis Lee Date 6-12 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				<div style="position: absolute; right: -100px; top: 50%; transform: translateY(-50%); font-size: 2em; font-weight: bold;">10-9-E-14 N.W. NEUE</div>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5