


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County <u>Pottawatomie</u>	Township name <u>St. George</u>	Fraction <u>SW 1/4 - SW 1/4</u>	Section number <u>14</u>	Town number <u>105</u>	Range number <u>9E</u>		
Distance and direction from nearest town or city: Street address of well location if in city:				3 Owner of well: <u>James Piper</u> Address: <u>Manhattan, Ks.</u>					
Locate with "X" in section below: N  W E S 1 Mile		Sketch map: <u>75' x 60'</u>		4 Well depth: <u>54</u> ft. Date of completion: <u>4/21/75</u> Well diameter <u>10</u> in.					
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
		Sand + Clay		0		5		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
		Blue Clay		5		27		7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>25</u> in. Diam. Weight <u>233</u> lbs./ft. <u>5</u> in. to <u>54</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u> </u> in. to <u> </u> ft. depth	
Yellow Clay		27		46		8 Screen: Manufacturer <u>Pump Co</u> Type <u>A/C</u> Dia. <u>5"</u> Slot/gauge <u>.025</u> Length <u>10</u> Set between <u>37</u> ft. and <u>54</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>#3</u>			
Coarse sand & gravel		46		54		9 Static water level: <u>18</u> ft. below land surface Date <u>5-21-75</u>			
						10 Pumping level below land surfaces: <u>AIR TEST</u> <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>30</u> g.p.m.			
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>			
						12 Well head completion: <u>capped</u> <input type="checkbox"/> Pitless adapter <u>24</u> <input type="checkbox"/> Inches above grade			
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.			
						14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>EAST</u> Type <u>S.T.</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation <u>650</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Stroder Drilling Co, Inc #182</u> Business name License No. Address <u>411 Hwy 2810, Manhattan, Ks</u> Signed <u>Walt Cochran</u> Date <u>5-23-75</u> Authorized representative					