

41

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County RILEY	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 1819	Township number T 10 S R 9	Range number 9	QW
2. Distance and direction from nearest town or city: 1 N - 1 1/2 W of ZEANDALE, KANSAS			3. Owner of well: JOHN HOLLE				
Street address of well location if in city:			R.R. or street: RR # 3				
			City, state, zip code: MANHATTAN, KANSAS 66502				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 30 in. Completion date 95		
					Well depth 54 ft. 7/17/75		
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
					9. Casing: Material AC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 1 1/2 in. to <input type="checkbox"/> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 30		
5. Type and color of material		From	To	10. Screens: Manufacturer's name JOHNSON			
TOP SOIL + CLAY		0	21	CONCRETE - HASTINGS WEB			
SAND		21	26	Type ASBESTOS CEMENT Dia. 16			
GRAVEL		26	33	Slot/groove 1/8" Length 26			
CLAY		33	38	Set between 28 ft. and 54 ft.			
GRAVEL		38	40	Gravel pack? YES Size range of material 1/4" - 1/2"			
GOOD GRAVEL		40	54	11. Static water level: 27 ft. below land surface Date 7/17/75			
SHALE		54		12. Pumping level below land surfaces: 45 ft. after 2 hrs. pumping 1200 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1800 g.p.m.			
				13. Water sample submitted: NO ma./day/yr.			
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
				15. Well grouted? NO With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From ____ ft. to ____ ft.			
				16. Nearest source of possible contamination: ft. 300 Direction W Type SEPTIC TANK Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation: 1000	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX + SONS, INC 258 Business name _____ License No. _____ Address CLIFTON KANSAS Signed Francis Cox Date 11-28 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

T 10 S R 9
 NE 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5