

51

Alma

R  
vid

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

ABB

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

NW 1/4 - NW 1/4 - NE 1/4

1. Location of well: County <u>Wabaunsee</u> Fraction <del>NE 1/4 NE 1/4 NW 1/4</del> Section number <u>31</u> Township number <u>T 11 S</u> Range number <u>R 10</u> <u>EW</u>	
2. Distance and direction from nearest town or city: <u>3 N / 3 W</u> Street address of well location if in city: <u>Alma, Ks.</u>	
3. Owner of well: <u>Eric Nelson</u> R.R. or street: <u>Box 128 Rt. 1</u> City, state, zip code: <u>Alma, Ks. 66401</u>	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. <u>8</u> in. Completion date <u>8-17-78</u> Well depth <u>140</u> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <u>PVC</u> Height: <u>above</u> or below Threading: <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP: <input type="checkbox"/> PVC <u>blue</u> Weight <u>2.74</u> lbs./ft. Dia. <u>5</u> in. to <u>140</u> ft. depth Wall Thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>258</u>	
5. Type and color of material	
	From To
<u>Top Soil &amp; Limestone Rock</u>	<u>0 2</u>
<u>yellow limestone</u>	<u>2 10</u>
<u>Tan limestone</u>	<u>10 11</u>
<u>Tan &amp; Gray Shaley Limestone</u>	<u>11 44</u>
<u>Gray Shale</u>	<u>44 49</u>
<u>Tan &amp; yellow Shaley Limestone</u>	<u>49 68</u>
<u>Gray Shaley limestone</u>	<u>68 75</u>
<u>Gray Shale</u>	<u>75 125</u>
<u>Brown Shale</u>	<u>125 130</u>
<u>Gray Shale</u>	<u>130 140</u>
(Use a second sheet if needed)	
10. Screen: Manufacturer's name <u>Pumpco</u> Type <u>PVC</u> Dia. <u>5"</u> Slo/gauze <u>090</u> Length <u>60'</u> Set between <u>40</u> ft. and <u>90</u> ft. <u>130</u> ft. and <u>140</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>4x4x8</u>	
11. Static water level: <u>50</u> ft. below land surface Date <u>8-17-78</u> ma./day/yr.	
12. Pumping level below land surfaces: <u>hi-test</u> <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>1 (one)</u> g.p.m.	
13. Water sample submitted: <u>   </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>   </u>	
14. Well head completion: <u>Top Cap</u> <input type="checkbox"/> Pitless adapter <u>24</u> Inches above grade	
15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
16. Nearest source of possible contamination: <u>300</u> ft. Direction <u>S</u> Type <u>laterals</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>   </u> Model number <u>   </u> HP <u>   </u> Volts <u>   </u> Length of drop pipe <u>   </u> ft. capacity <u>   </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: <u>1775'</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>owner to install slab.</u>
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>STRADER Dalg Co</u> <u>182</u> Business name License No. Address <u>RT1 HALLAM KS</u> Signed <u>Dale Ashm</u> Date <u>8-21-78</u> Authorized representative	

T  
R  
E  
W  
11 100  
31  
1/4 1/4  
MENNEN