

VSD
R

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

Change

WATER WELL RECORD
KSA 82a-1201-1215

BDA Rev DR

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wabaunsee	Fraction NE SE NW SW 1/4 SW 1/4 SW 1/4	Section number #10	Township number T 11 R 11 EW	Range number R 11 EW
2. Distance and direction from nearest town or city: 3 N. 5 W. 2 N			3. Owner of well: John O Shea			
Street address of well location if in city: OF PAXICO			R.R. or street: RT 1			
			City, state, zip code: Hoyt, Ks. 66440			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date _____	
					Well depth 75 ft. 8-7-78	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					X Use: <input checked="" type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 96 Weight 2.58 lbs./ft. Dig. 5 in. to 75 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1279	
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____		
TOP SOIL		0	5	PUMPO MPF		
Clay BROWN		5	12	Type PVC Dia. 5		
GRAVEL-loose limestone		12	14	Sieve gauge 20 Length 10		
Shale, grey		14	75	Set between 12 ft. and 22 ft. ft. and _____ ft.		
				Gravel pack? <input checked="" type="checkbox"/> Size range of material: 0.30x0.60		
				11. Static water level: _____ mo./day/yr. 12 ft. below land surface Date 8-7-78		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 5 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: COP _____ Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 100 Direction S Type DRAINAGE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 119'		19. Remarks: OWNER TO INSTAL SLAB		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER Dalg CO Inc 182 Business name _____ License No. _____ Address RT 1 HAYTON, KS Signed Dale Ackson Date 8-15-78 Authorized representative		

1066

11-110-210
NE 1/4
SW 1/4
SE 1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5