

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

SW NE SW CAC

1 Location of well: County Wabaunsee		Township name		Fraction SW NE SW	Section number 16	Town number T11S	Range number R12E
Distance and direction from nearest town or city:				3 Owner of well: Spain, Richard			
Street address of well location if in city:				Address: RFD. Maple Hill, Ks.			
Locate with "X" in section below:			Sketch map:			4 Well depth: 63 ft. Date of completion: 2/20/75 Well diameter 10 in.	
						5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
						6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
						7 Casing: Material PVC Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 42 in. Diam. 5 in. to 63 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 63 ft. depth	
2			Type and color of material	From	To	8 Screen: Manufacturer Pumpco Supply Type PVC 200 Dia. 5 1/4" Slot gauge 1/4" Length 20 feet Set between 15 ft. and 63 ft. Fittings: 26 + 29 36 feet Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2"	
			Top Soil	0	4	9 Static water level: 10 ft. below land surface Date 2/20/75	
			Yellow Clay	4	7	10 Pumping level below land surfaces: 10 ft. after 2 hrs. pumping 7.5 g.p.m. 20 ft. after 4 hrs. pumping 6.5 g.p.m. Estimated maximum yield 6.5 g.p.m.	
			Yellow Clay with Sand	7	14	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
			Gravel and Granite Rock	14	16	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
			Blue Lime Rock	24	28	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 4 ft. to 14 ft.	
			Gray Shale	28	35	14 Nearest source of possible contamination: Pond ft. 50 Direction EAST Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
			Yellow Lime Rock	16	18	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			Gray Shale, Sand and Gravel	18	24	16 Remarks: elevation 3 Ft. Extra Perforations: 26 to 29 Ft.	
			Blue Shale	35	52	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cummings Drilling 148 Business name _____ License No. _____ Address Topeka Signed Paul The Cummings date 2/7/75 Authorized representative	
			Black Shale	52	53	16 Remarks: elevation 998 Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope to the East <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	
			Gray Shale	53	59		
			Lime Rock	59	63		
			Total: 63 Feet				
(use a second sheet if needed)							

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

BR =

▽ = 980