

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

NW - NE - SE

1. Location of well:		County WABASH CO	Fraction S 1/4 S 1/4 S 1/4 S 1/4	Section number 22	Township number T 11	Range number R 13
2. Distance and direction from nearest town or city: Street address of well location if in city: Willard			3. Owner of well: MRS. W. G. MUNN'S R.R. or street: 1535 Pembroke Lane City, state, zip code: Topeka, KS 66616			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. 10 in. Completion date _____ Well depth 80 ft. 9-27-77	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stack <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 92 Weight 2.58 lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 274	
					10. Screen: Manufacturer's name PUMPCO, MPE Type PVC Dia. 5 Slot/gauze .020 Length 10 Set between 18 ft. and 29 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material .030 X 1000	
					11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 9-27-77	
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 5 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
					14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 29 inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft..	
					16. Nearest source of possible contamination: ft. 150 Direction N Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation: 950' +/-		19. Remarks: owned to install slab OK RM		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DRIG Co Finc 182 Business name License No. _____ Address Halton, KS Signed Dale Ashum Date 9-28-77 Authorized representative		

11-13026-1/4 SUBSUSC

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5