

191

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County shawnee Fraction NW 1/4 NW 1/4 SW 1/4 Section number 3 Township number T 11 S R 13 E/W Range number	
2. Distance and direction from nearest town or city: 1 S of Street address of well location if in city: Rossville 3. Owner of well: Fern Rogers R.R. or street: City, state, zip code: RRI Rossville, KS 66538	
4. Locate with "X" in section below: Sketch map:	
5. Type and color of material	
Top soil	From 0 To 6
Clay, brown	6 29
Fine sand - coarse sand - med gravel	29 50
6. Bore hole dia. 12 in. Completion date 5-11-79 Well depth 50 ft.	
7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material PVC Height: 29 Above or below Threading: Welded Surface 29 in. RMP: PVC 96 Weight 282 lbs./ft. Dia. 3 in. to 50 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 1258	
10. Screen: Manufacturer's name Pumpco MPI Type PVC Dia. 5 Slot gauze 020 Length 10 Set between 40 ft. and 50 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 030X060	
11. Static water level: 21 ft. below land surface Date 5-11-79 mo./day/yr.	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.	
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
14. Well head completion: cap 24 Pitless adapter _____ Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.	
16. Nearest source of possible contamination: ft. 150 Direction NW Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____	
(Use a second sheet if needed)	
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: owner to install slab
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name STRADER DRlg Co Inc 182 License No. Address RTI HATION, KS Signed Dale Astum Date 5-14-79 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T
R
W
S
1/4
1/4
1/4
1/4