USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

BEL

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

		SE NW NU	1		Topeka, Kansas 66620
1. Location of well:	County	Fraction Near		on number	Township number Range number
	Shawnee	Ctrocwi xx NW		3	T 11 (s) R 13 (Ε/)
2. Distance and direct Rossville, 1 Street address of well	tion from nearest town or cit Ks. to N.W. 464 location if in city:	th St. & 3/4 mi. W.	R.A. or street:	Во	ncile Harvey ox 343 Baldwin, Kansas 66006
4. Locate with "X" in section below: N N N N N N N N N N N N N			Possivile, K.		6. Bore hole dia. 30 in. Completion date 3-29- Well depth 52 ft
			it.		B. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other
SW ! ! S	SE	↓	· ·		9. Casing: Material Trans Height: Above or below Threaded Welded !Surface in. RMP PVC Weight lbs./ft. Dig. 16. to 26 ft. depth Wall Thickness: inches or
5. Type and color of material			Fron	То	Diain. toft. depth gage No. •75"
Hard black gumbo			6	2	Johnson Well Co. Type Transite Dia 16"
Light brown silty sand			2	19	Slot/gauze 1/8x8 Length 26 Set between 26 ft. and 52 ft. ft. and ft.
Small brown gravel			19	23	Gravel pack? yes Size range of material
Med. to large brown gravel			23	28	11. Static water level: mo./day/yr
Fine green sand			28	29	12. Pumping level below land surfaces: 12. Pumping level below land surfaces: 12. Pumping level below land surfaces: 13. Pumping level below land surfaces: 14. Strain level below land surfaces: 15. Strain level below land surfaces: 16. Strain level below land surfaces:
Med. green gravel			29	3 6	40 ft. after 3 hrs. pumping 700 g.p.m. Estimated maximum yield 700 g.p.m.
Fine green sand			36	39	13. Water sample submitted: mo./day/yr. Yes X No Date
Med. to la	vel	39	40	14. Well head completion: Pitless adapter Inches above grade	
Fine gray sand				48	15. Well grouted? <u>Ves</u>
Med. gray gravel & clay				50	With: Neat cement Bentonite X Concrete Depth: From 0 ft . to 10 ft .
Med. to large gray gravel			50	52	16. Nearest source of possible contamination: ft. 1800 Direction NE Type creek
Med. to large gray gravel & hard gray clay			52		Well disinfected upon completion? Yes X No 17. Pump: X Not installed
Stopped-green shale.					Manufacturer's name HP Volts
					Length of drop pipe ft. capacityg.p.m.
					Type: Submersible Turbine
·	(Use a s	second sheet if needed)			Jet Reciprocating Other
18. Elevation: 9296/1. Topography: ———————————————————————————————————	19. Remarks:	do not install pump	s.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name Address St. Marys Ks. 66536