

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Shawnee	Fraction Ctr 1/4 of -- 1/4 NW 1/4	Section number 4	Township number T 11S	Range number S R 13E E/W
2. Distance and direction from nearest town or city: Rossville to N.W. 46th St. & 2 1/4 mi. West.			3. Owner of well: Joe Gresser R.R. or street: City, state, zip code: Rossville, Kansas 66533			
4. Locate with "X" in section below:		Sketch map: N. N.W. 46th St.			6. Bore hole dia. 30 in. Completion date 3-29-77 Well depth 46 ft.	
					7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Hard brown sandy silt		0		2		9. Casing: Material Steel Height: (Above) or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 25 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. .219 w.t.
Fine brown sand		2		14		10. Screen: Manufacturer's name Free-Flo W. A. Brown Enterprises Type steel Dia. 16" (Slot/gauze 1/8 x 2 Length 20' Set between 25 ft. and 45 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes size range of material 1/8-1/4"
Small brown gravel		14		18		11. Static water level: _____ mo./day/yr. 18.5 ft. below land surface Date 3-29-77
Med. to large brown gravel		18		20		12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 800 g.p.m. 35 ft. after 3 hrs. pumping 1000 g.p.m. Estimated maximum yield 1200 g.p.m.
Med. to large gray gravel & clay		20		24		13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Med. brown gravel		24		26		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Med. gray gravel		26		28		15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Med. gray gravel & clay		28		31		16. Nearest source of possible contamination: ft. 1300 Direction west Type Home & Feedlot Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Large gray gravel		31		38		17. Pump: <input checked="" type="checkbox"/> X Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Med. gray gravel		38		39		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name License No. Address St. Marys, Kansas 66536 Signed Don Hoobler Date 4-5-77 Authorized representative
Fine gray gravel		39		41		
Fine to med. gray gravel		41		42		
Med. to large gray gravel		42		44		
Gray clay		44		46		
Stopped.		46				
(Use a second sheet if needed)						
18. Elevation: 		19. Remarks: We do not install pumps.				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

12
130
7
1/4
1/4
2 NW