

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well: Shawnee		Fraction 1/4 Ctr. of 1/4 SE 1/4	Section number 5	Township number T 11 S	Range number R 13 (E) N
Distance and direction from nearest town or city: 1/2 mi. West of Rossville, Ks.			3. Owner of well: David Stadler		
Street address of well location if in city: 1/4 m. S. 1 3/4 m. W. of Rossville, Ks.			R.R. or street:		
City, state, zip code: Rossville, Kansas 66536			6. Bore hole dia. 30 in. Completion date 10-9-76		
4. Locate with "X" in section below: Sketch map:			Well depth 47 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top soil & fine sand			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine brown sand			9. Casing: Material Transite Height (Above) by below 12 in. Threading <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 21 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7/8		
Soft brown clay			10. Screen: Manufacturer's name Johnson Well		
Fine brown sand & brown clay			Type Transite Dia. 16"		
Hard gray sand & stone			Slot/gauze 1/8x8 Length 26'		
Small to med. brown gravel			Set between 47 ft. and 21 ft. and <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8		
Fine to med. green gravel			11. Static water level: 20' 3" ft. below land surface Date 10-9-76 mo./day/yr.		
Med. brown gravel			12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 800 g.p.m. 27 ft. after 3 hrs. pumping 800 g.p.m. Estimated maximum yield 900 g.p.m.		
Med. green gravel			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Med. to large green gravel			14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Stopped.			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
(Use a second sheet if needed)			16. Nearest source of possible contamination: ft. 3000 Direction south Type river Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
18. Elevation: 3 Rm			17. Pump: <input checked="" type="checkbox"/> Not installed		
19. Remarks: Set up for center pivot. We do not install pumps.			Manufacturer's name		
			Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/>		
			Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.		
			Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
			Hoobler Drilling Co. 323		
			Business name License No.		
			Address St. Marys, Ks. 66536		
			Signed Don Hoobler Date 10-29-76		
			Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

17
130
5
CSE
1/4 1/4 1/4