

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Shawnee</b>	Fraction <b>SW 1/4 NW 1/4 SW 1/4</b>	Section number <b>11</b>	Township number <b>T 13S</b>	Range number <b>S R 13E</b>	E/W <b>E/W</b>
2. Distance and direction from nearest town or city: <b>2 1/4 miles South of Rossville, Ks. on Carlson Road.</b>			3. Owner of well: <b>Laird French</b> R.R. or street: City, state, zip code: <b>Rossville, Ks.</b>				
4. Locate with "X" in section below: <b>Rossville, Ks.</b>					6. Bore hole dia. <b>30</b> in. Completion date <b>3-25-77</b> Well depth <b>48</b> ft.		
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Fine silty sand			0	19	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Small brown gravel			19	21	9. Casing: Material <b>Trans.</b> Height: (Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <b>16</b> in. to <b>22</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.75"</b>		
Med. to large brown gravel			21	24	10. Screen: Manufacturer's name <b>Johnson Well Co.</b> Type <b>Transite</b> Dia. <b>16"</b> (Slot) gauze <b>1/8 x 8</b> Length <b>26'</b> Set between <b>22</b> ft. and <b>48</b> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <b>yes</b> Size range of material <b>1/8-1/4"</b>		
Med. to large gray gravel			24	34	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>22</b> ft. below land surface Date <b>3-25-77</b>		
Med. gray gravel			34	35	12. Pumping level below land surfaces: <b>30</b> ft. after <b>1</b> hrs. pumping <b>800</b> g.p.m. <b>37</b> ft. after <b>3</b> hrs. pumping <b>1200</b> g.p.m. Estimated maximum yield <b>1300</b> g.p.m.		
Med. to large gray gravel & clay			35	38	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Med. to large gray gravel			38	48	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Hard brown till-stopped.			48		15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
					16. Nearest source of possible contamination: ft. <b>600</b> Direction <b>west</b> Type <b>road ditch</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Hoobler Drilling Co. 323</b> Business name License No. Address <b>St. Marys, Ks. 66536</b> Signed <b>Don Hoobler</b> Date <b>4-5-77</b> Authorized representative		
18. Elevation: <b>913RM</b>		19. Remarks: <b>We do not install pumps. Redrilled well.</b>					
Tapography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5