


198

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:		County Shawnee	Fraction Center NW 1/4 NW 1/4	Section number 12	Township number T 11 S	Range number R 13 (B/W)
X Distance and direction from nearest town or city: 2 mi. East & 3/4 mi. So. of Rossville, Ks. on U.S. 24			3. Owner of well: Harley C. McCoid			
Street address of well location if in city: + 1 mi. E. on NW 1/4 mi. S. on Carlson			R.R. or street: City, state, zip code: Rossville, Ks. 66533			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. 30 in. Completion date 10-24-76 Well depth 86 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
From To			9. Casing: Material Trans Height: (Above or below) Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 56 ft. depth Wall Thickness inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7/8			
			10. Screen: Manufacturer's name Johnson Well Type Transite Dia. 16 (Slot/gauze) 1/8x8 Length 30' Set between 56 ft. and 86 ft. Gravel pack? yes Size range of material 5/8			
Black top soil			0	2	11. Static water level: <input type="checkbox"/> mo./day/yr. 19 ft. below land surface Date 10-24-76	
Fine brown sand			2	5	12. Pumping level below land surfaces: 21 ft. after 1 hrs. pumping 1200 g.p.m. 27 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 2500 g.p.m.	
Brown clay			5	7	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date	
Fine brown sand			7	20	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Brown med. sand & some small gravel			20	26	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Brown med. to lge. gravel some gray clay			26	29	16. Nearest source of possible contamination: ft. 660 Direction West Type Road Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Brown med. to large gravel			29	31	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Green med. to large gravel & old tree			31	37	18. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name License No. Address St. Marys, Ks. 66576 Signed Don Hoobler Date 10-27-76 Authorized Representative	
Med. to fine gray sand & clay & old tree			37	42		
Med. to large gray gravel			42	52		
Small to med. brown gravel			52	54		
Med. to large gray gravel			54	63		
Med. to large brown gravel			63	86		
Stopped.			86			
(Use a second sheet if needed)						
18. Elevation: 925 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: We do not install pumps				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5