

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SW BCC

1. Location of well:		County Shawnee	Fraction SE 1/4 SW 1/4 NW 1/4	Section number 11	Township number T 11	Range number S R 14	B/W
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: Lilley, Ron Rt. 6 R.R. or street: City, state, zip code: Topeka Ks.			
4. Locate with "X" in section below: N W X E S 1 Mile				Sketch map:		6. Bore hole dia. 10 in. Completion date 11/16/76 Well depth 60 ft.	
5. Type and color of material				From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top soil				0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown clay with F. sand				3	15	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.258	
Yellow clay with F. sand				15	24	10. Screen: Manufacturer's name Morden Pipe Type PVC Dia. 5 in. Slot/gauze 1/4 Length 20 Set between 40 ft. and 60 ft. Gravel pack? Yes Size range of material 1/4	
Yellow clay with G. sand				24	32	11. Static water level 237 mo./day/yr. 23 ft. below land surface Date 11/16/76	
Sand and small Gravel				32	35	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 5 g.p.m.	
Sand shale				35	38	13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Blue lime rock				38	43	14. Well head completion: 3 Pitless adapter ____ Inches above grade	
Gray shale				43	60	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
(Use a second sheet if needed)						16. Nearest source of possible contamination: ft. 300 Direction West Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Slab to installed by customer use 910?		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cummings Drilling Co 148 Business name License No. Address 1319 Topeka Signed Frank Cummings Date 11/14/76 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 925 ∇ = 937