

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SE SE BEC BDI

1. Location of well:		County Shawnee	Fraction SW 1/4 SW 1/4 1/4	Section number 14	Township number T 11 S (3)	Range number R 14 (E)W
2. Distance and direction from nearest town or city: 1 E			3. Owner of well: Bob Hook			
Street address of well location if in city: OF SILVER LAKE			City, state, zip code: SILVER LAKE, KS 66539			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 19 in. Completion date 1-29-76 Well depth 50 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC GL Weight <input type="checkbox"/> lbs./ft. Dia. 8 in. to 50 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 410	
					10. Screen: Manufacturer's name RUMPCO Type PVC Dia. 8" Slot/gauze .080 Length 15' Set between 35 ft. and 50 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/2	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 22 ft. below land surface Date 1-29-76	
					12. Pumping level below land surfaces: AIR TEST <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 300 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: CAPPED <input type="checkbox"/> Pitless adapter 24 inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. 100 Direction N Type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name JACUZZI Model number 5566-52 HP 5 Volts 220 Length of drop pipe 42 ft. capacity 100 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stader Drilling Co Inc 182 Business name License No. Address RT1 Holton KS Signed Dale Peterson Date 1/31/76 Authorized representative	
18. Elevation: 906 RA		19. Remarks: OWNER WILL INSTALL SLAB				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5