

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

CBA
CBO
NE
SE NW SW

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Shawnee	Fraction NE 1/4 SW 1/4	Section number 9	Township number T 11 S	Range number R 15 W
2. Distance and direction from nearest town or city: 2 N 1 West			3. Owner of well: Ed Godfrey		
Street address of well location if in city: Topeka			R.R. or street: 3222 Sena		
			City, state, zip code: Topeka, Kansas 66604		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____	
				Well depth 60 ft. 7-6-77	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC BLUE Weight 2.74 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258	
5. Type and color of material		From To		10. Screen: Manufacturer's name MPI Ruxco	
Top Soil		0 10		Type PVC Dia. 5"	
Brown Fine Sand		1 3		Slot/gauze 080 Length 10	
Brown Clay Sandy		3 14		Set between 50 ft. and 60 ft.	
Brown Sandy Gravelly Clay		14 19		Gravel pack? yes Size range of material 1/4 x 1/4	
Tan Flower Sand		19 30		11. Static water level: _____ mo./day/yr. 40 ft. below land surface Date 7-6-77	
Brown Flint Gravel		30 33		12. Pumping level below land surfaces: Air test _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 6 g.p.m.	
Brown coarse sand		33 37		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Brown River Gravel		37 60		14. Well head completion: Top cap <input type="checkbox"/> Pitless adapter 24 inches above grade	
Gray Shale		60		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: #19 ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				18. Elevation: 940	
				19. Remarks: Owner will construct cement slab ground 16.- New Home Site - Proposed laterals 200' S.E.	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DELG Co Inc 182 Business name _____ License No. _____ Address RT 1 Holton, KS Signed Dale Adams Date 7-11-77 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 880 Δ = 900

956
60
10

11 150 - 9 NE SW 20