

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SE NW ABD

1. Location of well:		County Shawnee	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 10	Township number T 11	Range number S R 15	Q/W
2. Distance and direction from nearest town or city: 1 N Hwy-24, 1/4 W			3. Owner of well: Leon Green 4301 NW, 37				
Street address of well location if in city: 75 at Topeka			R.R. or street: Erick Dr.				
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 5 in. Completion date _____ Well depth 65 ft. 7-6-77		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material				From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil				0	3	9. Casing: Material PVC Height: Above or below Threading _____ Welded _____ Surface 24 in. RMP _____ PVC GLUE Weight 2.74 lbs./ft. Dia. 5 in. to 65 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258	
Brown Clay				3	9	10. Screen: Manufacturer's name MPI - Pumpco Type PVC Dia. 5" Slot gauze 080 Length 10 Set between 55 ft. and 65 ft. _____ ft. and _____ ft.	
Brown fine Sandy Silt				9	15	Gravel pack? <input checked="" type="checkbox"/> Size range of material 4x18	
Tan Sandy Clay				15	24	11. Static water level: _____ mo./day/yr. 45 ft. below land surface Date 7-6-77	
Tan Flower Silt				24	45	12. Pumping level below land surfaces: PICT _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 40 g.p.m.	
Tan Sugar silt				45	47	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Brown Flint Gravel large River Gravel				47	65	14. Well head completion: Top cap <input type="checkbox"/> Pitless adapter 24 Inches above grade	
Gray Shale						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: ft. 50 Direction SE Type lotterads Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)							
18. Elevation: 970		19. Remarks: owner will construct cement slab around well			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRAIDER DALE CO INC 182 Business name _____ License No. _____ Address HOLTON, KS Signed Dale Ashrum Date 7-7-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

BR = 905

▽ = 97.5

T 11 S R 15 Q/W