

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Shawnee	Fraction Ctr. 1/4 of Ne 1/4 SW 1/4	Section number 21	Township number T 11 S R 15 (E/W)	Range number
2. Distance and direction from nearest town or city: 3 mi. West on U.S. 24, 2 mi. So. of Topeka on Lower S.L. Rd. Street address of well location if in city:				3. Owner of well: Charles R. Mohler R.R. or street: 3539 Lower Silver Lake Rd. City, state, zip code: Topeka, Ks.		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W 1 Mile S E</div> <p>Sketch map:</p>				6. Bore hole dia. 30 in. Completion date 3-9-77 Well depth 55 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Trans. Height (Above) or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 29 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7/8		
				10. Screen: Manufacturer's name Johnson Well Co. Type Transite Dia. 16" Slot/gauze 1/8x8 Length 26' Set between 55 ft. and 29 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 5/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 14 ft. below land surface Date 12-2-76		
(Use a second sheet if needed)				12. Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 1000 g.p.m. 25 ft. after 3 hrs. pumping 1200 g.p.m. Estimated maximum yield 1500 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. <input type="checkbox"/> source of pollution <input type="checkbox"/> destination Septic Bldg. site 800' direction NW from 1/4 sec. 1/4 sec. 1/4 sec. Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name License No. Address St. Marys, Ks. 66536 Signed Don Hoobler Date 3-14-77 Authorized representative		
				19. Remarks: We do not install pumps. Set up for center pivot irrigation.		