WATER WELL RECORD KSA 82a-1201-1215 Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

Lec'

· R

			26	Dir			Water well Contractors) Topeka, Kansas 66620
	County	Staction NV	SW	Section	number	Township number	Range number
1. Location of well:	Shawnee	DE 1/4 NE 1/4	NE 1/4	1	7	т /1	s R 16 E/W
2. Distance and dire	ection from nearest town or city:	NE OF	3. Ow	ner of wel	I: 5 T	NE CAlhoun B	N WEELN
Street address of wel	I location if in city: To Pek	A	R.R. o	r street: / state, zip	code: To	peka, 15	66601
4. Locate with "X"		Sketch map:				6. Bore hole dia	
, <u> </u>		Building SIT	•			7. Cable tool Rot	
NW NE NE SePT							ted Bored Reverse rotary
						·	Public supply Industry
X-150-1				_		Irrigation Air conditioning Stock Lawn Oil field water Other	
SW SE						9. Casing: Material	Height: Above or below
						Threaded Welded	iSurface 24 in Weight 2.82 lbs./ft
1 Mile ————————————————————————————————————						Dia. 5 in. to 10 ft.	depth Wall Thickness: inches or
5. Type and color of	f material			From	То	10. Screen: Manufacture	depth gage No. 258
1- 6	30.44.			à	,	PUMPCO 1	nPI
Top 5				0	 	Type PUC (Slo)/gauze 1030	Dia3 Length0
Clay, bi	TOW N			6	21	Set betweenf	ft. and ft
Fineson	ud, Course SAND, wh	Her bearing		11	30	Gravel pack? Size	range of material <u>で多の人であ</u>
Shale,91	oy, Limestone, q	rrey		30	40	11. Static water level:	surface Date 4->>-79
	0	J				12. Pumping level below	land surfaces:
						ft. after ft. after	hrs. pumping g.p.m. hrs. pumping g.p.m.
				†		Estimated maximum yield	30 g.p.m.
				+	-	13. Water sample submitte Yes No	d: mo./day/yr
					14. Well head completion	CAP	
					Pitless adapter 15. Well grouted?	Inches above grade	
				With: Negt cem		Bentonite Concrete	
						Depth: From ft.	
						ft. 150 Direction	
						Well disinfected upon cor	
					17. Pump: Manufacturer's name	Not installed	
					Model number	HP Volts	
				1		Type:	ft. capacityg.p.m.
				-	ļ .	Submersible Jet	Turbine Reciprocating
	(Use a secon	nd sheet if needed)				Centrifugal	Other
18. Elevation:	19. Remarks:				20. Water well contracto	r's certification: or my jurisdiction and this report	
8/07m	owner 40 install slab				is true to the best of my k	, ,	
Topography:Hill		VIAIT OILD				STRAJER DRIG Business name	Co Inc 182
Slope						Address RTI Ho	ITOn, Ks
Upland Valley						Signed Authorized	representative Date 4-30-