

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

SW
NW
NE
WATER WELL RECORD
KSA 82a-1201-1215
ABC

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SHAWNEE	Fraction SW 1/4 NE 1/4	Section number 28	Township number T 11 S R 16 E 10	Range number 16																								
2. Distance and direction from nearest town or city: Street address of well location if in city: 1003 FOREST			3. Owner of well: F. E. SHERWIN R.R. or street: 1003 FOREST City, state, zip code: TOPEKA KAN. 66616																											
Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 5 in. Completion date 6-16-76 Well depth 45 ft.																										
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																										
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																										
<table border="1"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Top soil (black)</td> <td>0</td> <td>4</td> </tr> <tr> <td>Hard pan Gumbo</td> <td>4</td> <td>6</td> </tr> <tr> <td>Silty brown clay</td> <td>6</td> <td>14</td> </tr> <tr> <td>" Sand</td> <td>14</td> <td>28</td> </tr> <tr> <td>Gray "</td> <td>28</td> <td>30</td> </tr> <tr> <td>SAN + GRAVEL</td> <td>30</td> <td>38</td> </tr> <tr> <td>GRAVEL</td> <td>38</td> <td>44</td> </tr> </tbody> </table>					From	To	Top soil (black)	0	4	Hard pan Gumbo	4	6	Silty brown clay	6	14	" Sand	14	28	Gray "	28	30	SAN + GRAVEL	30	38	GRAVEL	38	44	9. Casing: Material _____ Height: (Above or below) _____ Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 206		
	From	To																												
Top soil (black)	0	4																												
Hard pan Gumbo	4	6																												
Silty brown clay	6	14																												
" Sand	14	28																												
Gray "	28	30																												
SAN + GRAVEL	30	38																												
GRAVEL	38	44																												
				10. Screen: Manufacturer's name Sun-Low Plastics Type RMP Dia. 5" Slot/gauze 1/8" Length 40" Set between 40 ft. and 45 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 16"																										
				11. Static water level: _____ mo./day/yr. 31 ft. below land surface Date 6-15-76																										
				12. Pumping level below land surfaces: 31 ft. after 1 hrs. pumping 160 g.p.m. 31 ft. after 2 hrs. pumping 160 g.p.m. Estimated maximum yield 40 g.p.m.																										
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____																										
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade																										
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 200 ft. to 10 ft.																										
				16. Nearest source of possible contamination: C.I. SEWER ft. 30' Direction W Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																										
				17. Pump: <input checked="" type="checkbox"/> installed Manufacturer's name WARD'S Model number _____ HP 1/2 Volts 115 Length of drop pipe 40' ft. capacity 350 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
18. Elevation: 880 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				19. Remarks: 4'x4'x4" SLAB INSTALLED 6-16-76 Emery E. Sherwin																										
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HAROLD L. BATTIT Business name _____ License No. _____ Address 905 N MICHIGAN 333 Signed H. L. Battit Date 6-16-76 Authorized representative																										

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5