

1 LOCATION OF WATER WELL  
 County: Shawnee Fraction NW 1/4 NW 1/4 NE 1/4 Section Number 34 Township Number T 11 S Range Number R 16 EW

Distance and direction from nearest town or city? EAST of Topeka Street address of well if located within city? 3535 SEWARD AVE, Topeka

2 WATER WELL OWNER: Tim Bohr  
 RR#, St. Address, Box #: 3535 SEWARD AVE  
 City, State, ZIP Code: Topeka Kansas 66616  
 Board of Agriculture, Division of Water Resources  
 Application Number:

3 DEPTH OF COMPLETED WELL: 50 ft. Bore Hole Diameter: 8 in. to 26 ft., and 5 in. to 50 ft.  
 Well Water to be used as:  
 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well  
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
 7 Lawn and garden only 10 Observation well  
 Well's static water level: 26 ft. below land surface measured on 4 month 14 day 1984 year  
 Pump Test Data: Well water was 29 ft. after 2 hours pumping 20 gpm  
 Est. Yield 175 gpm: Well water was \_\_\_\_\_ ft. after \_\_\_\_\_ hours pumping \_\_\_\_\_ gpm

4 TYPE OF BLANK CASING USED:  
 1 Steel  3 RMP (SR)  5 Wrought iron  8 Concrete tile Casing Joints: Glued  Clamped  
 2 PVC  4 ABS  6 Asbestos-Cement  9 Other (specify below) Welded \_\_\_\_\_  
 7 Fiberglass \_\_\_\_\_ Threaded \_\_\_\_\_  
 Blank casing dia: 5 in. to 43 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
 Casing height above land surface: 14 1/2 in., weight 1.5 lbs./ft. Wall thickness or gauge No. 214


TYPE OF SCREEN OR PERFORATION MATERIAL:  
 1 Steel  3 Stainless steel  5 Fiberglass  8 RMP (SR)  10 Asbestos-cement  
 2 Brass  4 Galvanized steel  6 Concrete tile  9 ABS  12 None used (open hole)  
 Screen or Perforation Openings Are:  
 1 Continuous slot  3 Mill slot  5 Gauzed wrapped  8 Saw cut  11 None (open hole)  
 2 Louvered shutter  4 Key punched  6 Wire wrapped  9 Drilled holes  
 7 Torch cut  10 Other (specify) \_\_\_\_\_  
 Screen-Perforation Dia: 5 in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
 Screen-Perforated Intervals: From 43 ft. to 50 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Gravel Pack Intervals: From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

5 GROUT MATERIAL:  Neat cement  2 Cement grout  3 Bentonite  4 Other \_\_\_\_\_  
 Grouted Intervals: From 4 ft. to 15 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 What is the nearest source of possible contamination:  
 1 Septic tank  4 Cess pool  7 Sewage lagoon  10 Fuel storage  14 Abandoned water well  
 2 Sewer lines  5 Seepage pit  8 Feed yard  11 Fertilizer storage  15 Oil well/Gas well  
 3 Lateral lines  6 Pit privy  9 Livestock pens  12 Insecticide storage  16 Other (specify below)  
 13 Watertight sewer lines \_\_\_\_\_  
 Direction from well: EAST How many feet: 103 ? Water Well Disinfected? Yes \_\_\_\_\_ No   
 Was a chemical/bacteriological sample submitted to Department? Yes \_\_\_\_\_ No  If yes, date sample \_\_\_\_\_  
 was submitted \_\_\_\_\_ month \_\_\_\_\_ day \_\_\_\_\_ year: Pump Installed? Yes  No \_\_\_\_\_  
 If Yes: Pump Manufacturer's name: Goold's Model No. 13EM HP 1/2 Volts 110  
 Depth of Pump Intake: 45 ft. Pumps Capacity rated at 13 gal./min.  
 Type of pump:  Submersible  2 Turbine  3 Jet  4 Centrifugal  5 Reciprocating  6 Other \_\_\_\_\_

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was  constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on \_\_\_\_\_ month \_\_\_\_\_ day \_\_\_\_\_ year  
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 406  
 This Water Well Record was completed on \_\_\_\_\_ month \_\_\_\_\_ day \_\_\_\_\_ year under the business name of DESCH Equipment by (signature) George V. Rank

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	3	Black Dirt			
3	7	Lt Bun silt			
7	10	" " clay			
10	19	" " silt			
19	24	" " clay & silt			
24	43	Medium sand			
43	50	Coarse Sand & Gravel			



ELEVATION:  
 Depth(s) Groundwater Encountered 1. 26 ft. 2. \_\_\_\_\_ ft. 3. \_\_\_\_\_ ft. 4. \_\_\_\_\_ ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY  
 T  
 R  
 EW  
 SEC  
 1/4  
 1/4  
 1/4