

USE TYPEWRITER OR BALL-POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <u>Jefferson</u>	Fraction <u>NE 1/4 NW 1/4 NE 1/4</u>	Section number <u>17</u>	Township number T <u>11</u> S R <u>17</u> E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: <u>Lyon John</u> R.R. or street: <u>Rural Route 1</u> City, state, zip code: <u>Grantville Kansas</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10"</u> in. Completion date <u>10/23/76</u> Well depth <u>72</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	1	9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>2 1/2 x 13</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>100</u> lbs./ft. Dia. <u>5 1/2</u> in. to <u>62</u> ft. depth Wall Thickness: inches or Dia. <u>5 1/2</u> in. to <u>72</u> ft. depth gage No. <u>188</u>		
Brown Clay with F sand		1	3	10. Screen: Manufacturer's name <u>Valley Steel</u> Type <u>Steel</u> Dia. <u>6 5/8</u> Slot/gauze <u>Hole</u> Length <u>7</u> ft. Set between <u>56</u> ft. and <u>62</u> ft. <u>PVC 5 1/2</u> ft. and <u>72</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>3</u>		
Yellow Clay with F Sand		3	16	11. Static water level: <u>28</u> ft. below land surface Date <u>10/27/76</u>		
Yellow Clay with C Sand		16	33	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>10</u> g.p.m.		
Yellow Clay with C Gravel		33	60	13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Gray shale		60	62	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ Inches above grade		
Blue shale		62	72	15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft.		
				16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>North</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name <u>Gould</u> Model number <u>7EH</u> HP <u>1</u> / <u>30</u> lbs. <u>230</u> Length of drop pipe <u>67</u> ft. capacity <u>7</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: <u>2109</u>		19. Remarks: <u>Concrete slab be installed by customer</u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Cummings Drilling Co 148</u> Business name License No. <u>13014</u> Address <u>13014</u> Signed <u>Shedore Cummings</u> Date <u>11/6/76</u> Authorized representative		

T  
R  
W  
E  
S  
E  
1/4  
1/4  
1/4  
1/4