

(REVISED 2-9-77)

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

adb

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

~~SE~~ - SE - NE

1. Location of well:		County JEFFERSON	Tract NE SE 1/4 NE 1/4 NE 1/4	Section number 19	Township number T 11	Range number S 17 E 10
2. Distance and direction from nearest town or city: SOUTH SIDE GRANTVILLE			3. Owner of well: KAW TOWN SHIP GRANTVILLE COMMUNITY CENTER R.R. or street: City, state, zip code: BOB BIGGAM TREAS.			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. _____ in. Completion date 1-3-77 Well depth 41 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
TOP SOIL				0	7	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface _____ in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft.
SILT SOIL				7	13	Dia. 5 in. to 41 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 300
HARD PAN (BLACK)				13	16	10. Screen: Manufacturer's name SUNFLOWER
FINE SAND				16	20	Type SLOT Dia. 5" Slot/gauze 1/4 2 1/2" Length 5' Set between 4 3/8 ft. and 4 1 ft. _____ ft. and Bottom ft.
SAND + CLAY				20	29	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"
FINE SAND + GRAVEL				29	41	11. Static water level: _____ mo./day/yr. 29 ft. below land surface Date 12-10-76
(Use a second sheet if needed)						12. Pumping level below land surfaces: 32 ft. after 1 hrs. pumping 16 g.p.m. 30 ft. after 1 hrs. pumping 10 g.p.m. Estimated maximum yield 14 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
						14. Well head completion: <input type="checkbox"/> Pitless adapter 30 Inches above grade
						15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 22 ft.
						16. Nearest source of possible contamination: ft. 100' Direction S-W Type ST Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: 72 80'	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. H.L. PETTIT 333 Business name _____ license No. _____ Address 905 N. MICHIGAN Signed H.L. Pettit Date 2-9-77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR < 828
= 840