

16

adb

VBRT

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NW SE NE 27

X Location of well: Jefferson County		Fraction C & NE		Section number Survey 27		Township number T 11S		Range number S R 17E		E/W																																		
1. Distance and direction from nearest town or city: 3 mi. East of Grantville, Ks. on U.S. 24, & 1/4 mi. South.				2. Owner of well: John Reser R.R. or street: R. R. #6 City, state, zip code: Topeka, Kansas 66608																																								
4. Locate with "X" in section below:				Sketch map:				6. Bore hole dia. 30 in. Completion date 4-3-77 Well depth 50 ft.																																				
								7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																																				
5. Type and color of material				<table border="1"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr><td>Soft black soil</td><td>0</td><td>3</td></tr> <tr><td>Fine brown sandy soil</td><td>3</td><td>18</td></tr> <tr><td>Fine to med. brown gravel</td><td>18</td><td>23</td></tr> <tr><td>Fine brown sand</td><td>23</td><td>26</td></tr> <tr><td>Small to med. gray gravel & clay</td><td>26</td><td>31</td></tr> <tr><td>Small to med. gray gravel</td><td>31</td><td>33</td></tr> <tr><td>Med. to large gray gravel</td><td>33</td><td>37</td></tr> <tr><td>Fine gray sand</td><td>37</td><td>39</td></tr> <tr><td>Med. to large gray gravel</td><td>39</td><td>50</td></tr> <tr><td>Gray shale-stopped.</td><td>50</td><td></td></tr> </tbody> </table>					From	To	Soft black soil	0	3	Fine brown sandy soil	3	18	Fine to med. brown gravel	18	23	Fine brown sand	23	26	Small to med. gray gravel & clay	26	31	Small to med. gray gravel	31	33	Med. to large gray gravel	33	37	Fine gray sand	37	39	Med. to large gray gravel	39	50	Gray shale-stopped.	50		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
	From	To																																										
Soft black soil	0	3																																										
Fine brown sandy soil	3	18																																										
Fine to med. brown gravel	18	23																																										
Fine brown sand	23	26																																										
Small to med. gray gravel & clay	26	31																																										
Small to med. gray gravel	31	33																																										
Med. to large gray gravel	33	37																																										
Fine gray sand	37	39																																										
Med. to large gray gravel	39	50																																										
Gray shale-stopped.	50																																											
				9. Casing: Material Trans. Height (Above or below) 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 26 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 75				10. Screen: Manufacturer's name Johnson Well Co. Type Transite Dia. 16" (Slot) gauze 1/8 x 8 Length 26' Set between 24 ft. and 50 ft. and _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/8-1/4																																				
				11. Static water level: _____ mo./day/yr. 23 ft. below land surface Date 4-3-77				12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 800 g.p.m. 42 ft. after 3 hrs. pumping 1000 g.p.m. Estimated maximum yield 1200 g.p.m.																																				
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade																																				
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				16. Nearest source of possible contamination: ft. 1500 Direction East Type home Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																				
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				18. Elevation: 860 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley																																				
19. Remarks: We do not install pumps.				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name _____ License No. _____ Address St. Marys, Ks. 66536 Signed Don Hoobler Date 4-13-77 Authorized representative																																								

(Use a second sheet if needed)

BR = 810

11-170-22 C N 1/2