

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

C a a

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

N E N E S W

1. Location of well: County Jefferson		Fraction SW NE NE 1/4 SE 1/4 NW 1/4		Section number 30		Township number T 11 S R 17 E E/W		Range number	
2. Distance and direction from nearest town or city: 1/2 S 1/2 W 1/2 S of Grantville				3. Owner of well: Virgil McPherson R.R. or street: Rt 3 City, state, zip code: Topeka, KS 66439					
4. Locate with "X" in section below:				Sketch map:					
5. Type and color of material				From		To		6. Bore hole dia. 8 in. Completion date 10-2-78 Well depth 46 ft.	
Top Soil				0		3		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Loamy Clay				3		16		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sand Fine				16		27		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 6 in. to 46 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200	
Sand Fine-Med dirty				27		36		10. Screen: Manufacturer's name Sunflow Type RMP Dia. 6" Slot/gauze 0.50 Length 10 Set between 36 ft. and 46 ft. _____ ft. and _____ ft. Gravel pack? No Size range of material _____	
Sand Med-coarse dirty				36		46		11. Static water level: _____ mo./day/yr. 19 ft. below land surface Date 10-2-78	
								12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20+ g.p.m.	
								13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
								14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade	
								15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 18 ft.	
								16. Nearest source of possible contamination: ft. 100+ Direction North type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)									
18. Elevation: 868 as		19. Remarks: owner to install cement slab				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Robison Drilling 316 License No. _____ Address Perry, KS Signed Jack Robison Date 10-2-78 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR < 822

V B 11
 T 11 170 30
 R
 W
 S
 SE NW
 1/4 1/4 1/4