

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

VBRT
not used

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NW NESE

etc
dab

1. Location of well: County Jefferson		Fraction SW 1/4 SE 1/4 NE 1/4		Section number 8		Township number T 11 S R 18		Range number 18																																	
2. Distance and direction from nearest town or city: 4 Mi N.W., Perry, Ks.				3. Owner of well: U.S. Govt. Corps of Engineers Perry Project Office																																					
Street address of well location if in city:				City, state, zip code: Perry, Ks																																					
4. Locate with "X" in section below:				Sketch map:				6. Bore hole dia. 18 in. Completion date 4-26-78																																	
								Well depth 54 ft.																																	
5. Type and color of material				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry																																	
				<table border="1"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Topsoil</td> <td>0'0"</td> <td>0'6"</td> </tr> <tr> <td>Brown Clay</td> <td>0'6"</td> <td>23'6"</td> </tr> <tr> <td>Brown Clay, some sand</td> <td>23'6"</td> <td>27'6"</td> </tr> <tr> <td>Gray Sandy Clay</td> <td>27'6"</td> <td>30'0"</td> </tr> <tr> <td>Gray Silty Clay</td> <td>30'0"</td> <td>36'0"</td> </tr> <tr> <td>Gray Sandy Clay</td> <td>35'0"</td> <td>39'0"</td> </tr> <tr> <td>Gray Medium to Fine Sand</td> <td>39'0"</td> <td>46'6"</td> </tr> <tr> <td>Gray Coarse Sands, some Gravel</td> <td>46'6"</td> <td>51'6"</td> </tr> <tr> <td>Gray Shale</td> <td>51'6"</td> <td>53'6"</td> </tr> </tbody> </table>					From	To	Topsoil	0'0"	0'6"	Brown Clay	0'6"	23'6"	Brown Clay, some sand	23'6"	27'6"	Gray Sandy Clay	27'6"	30'0"	Gray Silty Clay	30'0"	36'0"	Gray Sandy Clay	35'0"	39'0"	Gray Medium to Fine Sand	39'0"	46'6"	Gray Coarse Sands, some Gravel	46'6"	51'6"	Gray Shale	51'6"	53'6"	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other			
	From	To																																							
Topsoil	0'0"	0'6"																																							
Brown Clay	0'6"	23'6"																																							
Brown Clay, some sand	23'6"	27'6"																																							
Gray Sandy Clay	27'6"	30'0"																																							
Gray Silty Clay	30'0"	36'0"																																							
Gray Sandy Clay	35'0"	39'0"																																							
Gray Medium to Fine Sand	39'0"	46'6"																																							
Gray Coarse Sands, some Gravel	46'6"	51'6"																																							
Gray Shale	51'6"	53'6"																																							
				9. Casing: Material Steel Height: Above or below				10. Screen: Manufacturer's name Johnson																																	
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 2'6" in.				Type Wire-round Dia. 8"																																	
				RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 28.6 lbs./ft.				Slot/gauze 40 Length 22'																																	
				Dia. 8 in. to 22.5 ft. depth				Set between 29.5 ft. and 51.5 ft.																																	
				Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth				Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 0.10"																																	
				11. Static water level: 2' ft. below land surface Date 4-26-78				12. Pumping level below land surfaces:																																	
				15' ft. after 1 hrs. pumping 130 g.p.m.				Estimated maximum yield 200 g.p.m.																																	
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date				14. Well head completion:																																	
				15. Well grouted? <input checked="" type="checkbox"/> YES				Pitless adapter 30 inches above grade																																	
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete				16. Nearest source of possible contamination:																																	
				Depth: From 0 ft. to 10 ft.				ft. 300' Direction S Type Road																																	
				17. Pump: <input checked="" type="checkbox"/> Not installed				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																	
				Manufacturer's name				18. Elevation: 850'																																	
				Model number				Topography:																																	
				Length of drop pipe				<input type="checkbox"/> Hill																																	
				Type:				<input type="checkbox"/> Slope																																	
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine				<input type="checkbox"/> Upland																																	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating				<input checked="" type="checkbox"/> Valley																																	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				19. Remarks: Pressure relief well, Corps constructed under round discharge																																	
				20. Water well contractor's certification:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.																																	
				Business name Layne Western Co. Inc. MA9				License No.																																	
				Address 110 W. 37th St. K.C. Mo.				Signed D. J. S. [Signature] Date 11-27-78																																	
				Authorized representative																																					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR abn = 799
I = 798

T
R
Sec
1/4
1/4
1/4
1/4