

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

cdc

1118E 8CNUSE
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

SWSESW

1 Location of well:		County Jefferson	Township name 11	Fraction NW 1/4 SE 1/4	Section number 8	Town number T11S	Range number R18E	
Distance and direction from nearest town or city: Perry - 2 miles SE			3 Owner of well: Eugene Schofer					
Street address of well location if in city: 2 NE of Perry.			Address: Perry Kans 66073					
Locate with "X" in section below:		Sketch map:			4 Well depth: 69' ft. Date of completion 7/12/75 Well diameter 6" in.			
		NW 1/4 SE 1/4 Sec 8 Township 11 Range 18 Jeff Co.			5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
					7 Casing: Material Steel Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. Diam. 6 1/2" Weight 13 lbs./ft. 6 in. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No			
2		Type and color of material			From	To	8 Screen: Manufacturer Field Type Perforated cutting tool Slot/gauze 1/8" Length 3 Set between 69 ft. and 66 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material	
		Top Soil			0	5	9 Static water level: 22 ft. below land surface Date 7/12/75	
		Clay			5	50	10 Pumping level below land surfaces: 33 ft. after 2 hrs. pumping 45 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
		Sandy Clay			50	55	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
		Sand			55	69	12 Well head completion: <input type="checkbox"/> Pitless adapter 50 inches above grade	
		Shale					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 15 ft.	
							14 Nearest source of possible contamination: ft. 600 Direction N Type Farm Bldg Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
							15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation 858'		Owner to install cement slabs.					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Robson Drilling 316 Business name _____ License No. _____ Address Carbondale, Mo. Signed Jack Robson Date 7/12/75 Authorized representative	

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

BR = 789
 □ = 836