

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

bcbdb

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <i>Jefferson</i>	Fraction <i>NW 1/4 SW 1/4 NW 1/4</i>	Section number <i>9</i>	Township number <i>T 11 S R 18 E</i>	Range number <i>18</i>
2. Distance and direction from nearest town or city: <i>4 Mi. N.W. Perry, Ks.</i>			3. Owner of well: <i>U.S. Govt. Corps of Engineers</i> R.R. or street: <i>Perry Project Office</i> City, state, zip code: <i>Perry, Ks.</i>			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <i>18"</i> in. Completion date <i>5-2-78</i> Well depth <i>71'6"</i> ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
<i>Topsoil</i>		<i>0'0"</i>	<i>0'6"</i>	9. Casing: Material <i>STEEL</i> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <i>30"</i> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <i>28.6</i> lbs./ft. Dia. <i>8</i> in. to <i>42.5</i> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <i>0.322"</i>		
<i>Brown Clay</i>		<i>0'6"</i>	<i>7'6"</i>	10. Screen: Manufacturer's name <i>Johnson</i> Type <i>Wire wound</i> Dia. <i>8"</i> Slot/gauze <i>40</i> Length <i>29'</i> Set between <i>29'</i> ft. and <i>21.5</i> ft. ft. and <input type="checkbox"/> ft.		
<i>Gray Clay</i>		<i>7'6"</i>	<i>10'0"</i>	Gravel pack? <i>yes</i> Size range of material <i>0.10"</i>		
<i>Brown Clay</i>		<i>10'0"</i>	<i>20'0"</i>	11. Static water level: <input type="checkbox"/> mo./day/yr. <i>6.15</i> ft. below land surface Date <i>5-4-78</i>		
<i>Gray Silty Clay</i>		<i>20'0"</i>	<i>30'0"</i>	12. Pumping level below land surfaces: <i>20'0</i> ft. after <i>1</i> hrs. pumping <input type="checkbox"/> g.p.m. <i>24.8</i> ft. after <i>1</i> hrs. pumping <i>170</i> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
<i>Gray Medium Silty Sand</i>		<i>30'0"</i>	<i>32'6"</i>	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
<i>Gray Fine to Medium Sand</i>		<i>32'6"</i>	<i>36'0"</i>	14. Well head completion: <input type="checkbox"/> Pitless adapter <i>30</i> Inches above grade		
<i>Gray Coarse Sand</i>		<i>36'0"</i>	<i>49'6"</i>	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <i>0</i> ft. to <i>15</i> ft.		
<i>Gray Silty Sand Clay</i>		<i>49'6"</i>	<i>57'6"</i>	16. Nearest source of possible contamination: ft. <i>300</i> Direction <i>S</i> Type <i>Road</i> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<i>Gray Silty Clay Fine Sand</i>		<i>57'0"</i>	<i>65'0"</i>	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
<i>Gray Sandy Gravel</i>		<i>65'0"</i>	<i>67'0"</i>			
<i>Gray Shale</i>		<i>67'0"</i>	<i>69'0"</i>			
(Use a second sheet if needed)						
18. Elevation: <i>8750</i>		19. Remarks: <i>Pressure relief well, Corps constructed underground discharge</i>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Layne Western Co. Inc. 149</i> Business name License No. Address <i>1010 W 37th K.C. Mo.</i> Signed <i>Dal B. ...</i> Date <i>11/30/78</i> Authorized representative	
Topography: <input type="checkbox"/> Hill <i>way</i> <input type="checkbox"/> Slope <i>850</i> <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR elev = 783

▽ : 788