## WATER WELL RECORD LC C

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	NO SW NO			Topeka, Kansas 66620
County  1. Location of well:	FractionOn West line	O Section	number	Township number Range number
Jefferson	1/4 1/4 <b>NW</b> 1/4	Fict	20	T 11S S R 18E E/W
24 bistance and direction from nearest town or city: 1½ South from Perry; K	mi. West on US 3.	Owner of well	Lam	ry Glaser, M. D.
Street address of well location if in city				
		ty, state, zip	code: Sr	nawnee Mission, Kansas
4. Locate with "X" in section below:  Kentu Ky Turslo. U.S. 24			1->	6. Bore hole dia. 30 in. Completion date 4-7-77  Well depth 50 ft.
The state of the s	\	1		7 Cable tool Rotary Driven Dug
- NV NE Suevay 17 E				Hollow rod Jetted Bored X Reverse rotary
				8. Use: Domestic Public supply Industry
× × × / / / //				Irrigation Air conditioning Stock
5\				Lawn Oil field water Other  9. Casing: Material Tans   Height: Above or below
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			Threaded Welded Surface 24in.	
5 -010 N.S. 24-			RMPPVCWeightlbs./ft.	
1 Mile → 1		5	Τ.	Dia. 16 in. to 24 ft. depth Wall Thickness: inches or Diain. to ft. depth gage No75**
5. Type and color of material		From	То	10. Screen: Manufacturer's name
Word block and				Johnson Well Co.
Hard black soil		- 0 -	2	Type <u>Transite</u> Dia. <u>16"</u> (Sloi) gauze <u>1/8 x 8</u> Length <u>26'</u>
Hard light brown sand		2	7	Set between 24 ft. and 50 ft.
Gray clay		2	28	
Gray Clay		<del></del>	20	Gravel pack? <b>Yes</b> Size range of material /8-1/4"  11. Static water level: mo./day/yr.
Med. green gravel		28_	35	21 ft. below land surface Date 4-7-77
Med. to large green gravel		35	38	12. Pumping level below land surfaces:
				32 ft. after 1 hrs. pumping 400 g.p.m. 45 ft. after 3 hrs. pumping 500 g.p.m.
Med. to large green gravel	& clay	38	40	Estimated maximum yieldg.p.m.
Med. to large green gravel		40	50	13. Water sample submitted: mo./day/yr.
Hard green shale-stopped.		50		Yes X No Date
S. C.		1	<del> </del>	14. Well head completion: Pitless adapter Inches above grade
			ļ	15. Well grouted? <b>Yes</b> _
				With: Neat cement Bentonite _X Concrete Depth: From _0 ft. to10 ft.
				16. Negrest source of possible contamination: ft. 1500 Direction SW Type Farmstead
				Well disinfected upon completion?YesXNo
				17. Pump: X Not installed
A-1				Model number HP Volts
				Length of drop pipe ft. capacityg.p.m.   Type:
				Submersible Turbine
				Jet Reciprocating
(Use a second sheet if needed)  18. Elevation: 19. Remarks:			Centrifugal Other Other	
For flood in	igation.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report
64				is true to the best of my knowledge and belief.
Topography: We do not ins	carr bumbs.			Hoobler Drilling Co. 323
Slope				Address St. Marys Ks. /66536
Upland				Signed Nan Horbelle Date 4-13-77
_X Valley				Autherited representative

Forward the white, blue and pink copies to the Department of Health and Environment  $\mathcal{BK}=80$ 

EK = 830

Form WWC-5

P 04