USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

(b) vBR1

17

T	R	EW	sec	1/4	1/4	1/4	No.

WATER WELL RECORD
KSA 82a-1201-1215

cbd

SE NW SW

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Jefferson	Rural	~~SW 1/4~~	29	11S	19E

Distance and direction from nearest town or city: In Williams Town

Street address of well location if in city: Lot #2 Block #8

3 Owner of well: Virgil A. Essman

Address: Perry Kansas 66073

Locate with "X" in section below:

N, W, E, S, 1 Mile

Sketch map: ~~Street~~

On separate sheet.

2 Type and color of material	From	To
Surface	0	16'
Sandy Shale (Grey in color)	16'	28'
Sand	28'	39'
Gravel	39'	61'

(use a second sheet if needed)

4 Well depth: 61 ft. Date of completion 5-31-77
Well diameter 6 in. O.D.

5 [X] Cable tool [ ] Rotary [ ] Driven [ ] Dug [ ] Hollow rod [ ] Jetted [ ] Bored [ ] Reverse rotary

6 Use: [X] Domestic [ ] Public supply [ ] Industry [ ] Irrigation [ ] Air conditioning [ ] Commercial [ ] Test well [ ]

7 Casing: Material Steel Height: above/below
Threaded [ ] Welded [X] Surface 12 in.
Diam. 6 in. to 61 ft. depth Weight 7 lbs./ft.
Drive shoe? [ ] Yes [ ] No
___ in. to ___ ft. depth

8 Screen:
Manufacturer Sunflower
Type Plastic Dia. 5"
Slot/gauze 1/32" Length 18'
Set between 60 ft. and 42 ft.
Fittings:
Gravel pack [ ] Yes [ ] No Size range of material

9 Static water level:
29 ft. below land surface Date 5-31-77

10 Pumping level below land surfaces:
33 ft. after 1 hrs. pumping 20 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 40 g.p.m.

11 Water sample submitted:
[ ] Yes [X] No Date

12 Well head completion:
[ ] Pitless adapter [X] Inches above grade

13 Well grouted? [X] Yes [ ] No
[X] Neat cement [ ] Bentonite [ ]
Depth: From 13 ft. to 3 ft.

14 Nearest source of possible contamination:
ft. 75 Direction East Type Septic
Well disinfected upon completion? [X] Yes [ ] No

15 Pump: [X] Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.m.p.
Type:
[ ] Submersible [ ] Turbine
[ ] Jet [ ] Reciprocating
[ ] Certrifugal [ ] Other

16 Remarks: elevation
FSX3 Land owner agrees to pour 4' square 4" thick concrete slab to meet state spec.

Topography:
[ ] Hill
[ ] Slope
[ ] Upland
[X] Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Perry Drilling Co K-155
Business name License No.
Address Perry Kansas 66073
Signed William Shumaker Date 6-2-77
Authorized representative

11 19E 29 SW SW

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

BR < 794
V = 826

677-H