

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Jefferson</u>	Township name <u>RURAL</u>	Fraction <u>NE 1/4</u>	Section number <u>30</u>	Town number <u>11</u>	Range number <u>19E</u>
Distance and direction from nearest town or city: <u>1/2 W. Williams Town</u>				3 Owner of well: <u>ISA STALLARD</u>		
Street address of well location if in city: <u>KS.</u>				Address: <u>RFD PERRY KANSAS</u>		
Locate with "X" in section below:		Sketch map:		4 Well depth: <u>63</u> ft. Date of completion <u>10-2-75</u> Well diameter <u>10</u> in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. Diam. <u>5</u> in. to <u>63</u> ft. depth Weight <u>2.33</u> lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
2		Type and color of material		From	To	8 Screen: Manufacturer <u>Pumpco</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauge <u>.080</u> Length <u>6</u> Set between <u>52</u> ft. and <u>58</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4" x 1/2"</u>
		<u>Top Soil</u>		<u>0</u>	<u>9</u>	9 Static water level: <u>NOT MEASURED</u> _____ ft. below land surface Date _____
		<u>Brown clay</u>		<u>4</u>	<u>45</u>	10 Pumping level below land surfaces: <u>AIR TEST</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>40</u> g.p.m.
		<u>COARSE SAND & some GRAVEL</u>		<u>45</u>	<u>57</u>	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		<u>Blue SHALE</u>		<u>57</u>	<u>63</u>	12 Well head completion: <u>CAPPED</u> <input type="checkbox"/> Pitless adapter <u>24</u> <input checked="" type="checkbox"/> Inches above grade
						13 Well grouted? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From _____ ft. to _____ ft.
						14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>N</u> Type <u>S. Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation <u>880'</u>				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Strader Drly Co Inc</u> <u>182</u> Business name License No. Address <u>RFD 1 Holton KS</u> Signed <u>Dale Caden</u> Date <u>10-5-75</u> Authorized representative		