

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Jefferson	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 30	Township number T 11 S	Range number R 19 E
2. Distance and direction from nearest town or city: 3 E-S Street address of well location if in city: S OF PERRY			3. Owner of well: MARVIN PARNEIL R.R. or street: City, state, zip code: PERRY, KS		
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 10px;"> </div> <div> <p>Sketch map: HOUSE SEPTIC well 50' - 50' - 50' - 50' DRAINAGE</p> </div> </div>			6. Bore hole dia. 10 in. Completion date 5-19-76 Well depth 60 ft.		
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 42 Weight 274.55 lbs./ft. Dia. 3 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 258 MNC		
5. Type and color of material			From	To	10. Screen: Manufacturer's name PUMPCO
Top Soil			0	6	Type PVC Dia. 5
yellow clay			6	30	Slot/gauge no Length 10
Fine Sand - Coarse Sand			30	45	Set between 50 ft. and 60 ft.
Coarse gravel			45	60	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4" x 1/8"
					11. Static water level: 30 ft. below land surface Date 5-19-76
					12. Pumping level below land surface: AIR TEST
					50 ft. after 5 hrs. pumping 50 g.p.m.
					50 ft. after 5 hrs. pumping 50 g.p.m.
					Estimated maximum yield 50 g.p.m.
					13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
					14. Well head completion: CAPPED
					Pitless adapter 24 inches above grade
					15. Well grouted? <input checked="" type="checkbox"/>
					With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete
					Depth: From 5 ft. to 15 ft.
					16. Nearest source of possible contamination: SEPTIC
					ft. 100 Direction E Type SEPTIC
					Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed
					Manufacturer's name
					Model number HP Volts
					Length of drop pipe ft. capacity g.p.m.
					Type:
					<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine
					<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
					<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: 855 Topography: 1514 <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			19. Remarks: OWNER WILL INSTALL SLAB		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DRLG CO INC 182 Business name License No. Address RT1 HOLTON, KS Signed Dale Strader Date 5-24-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5