WATER WELL RECORD KSA 820-1201-1215

| T | R | EW | sec 1/4 1/4 | 1/4 No. |
|---|---|----|-------------|---------|

Kansas State Dept. Of Health (Water Well Contractors) Forbes-Bldg. 740 Topeka, Kansas 66620

| | | | Topeka, Kalisas 00020 |
|------------------------------------------------------------------|------------------------------------------------------------------------------------------------|--------------------------------------------------|----------------------------------------------------------------------------------------------|
| 1 Location of well: Tettorson Rucal Fraction | Secti | on number | Town number Range number 115 19 E |
| Distance and direction from nearest town or city: Perry 5m/W 3 C | wner of wel | 1: Ge | orge Gantz |
| / | Address: | Pen | |
| Locate with "X" in section below: Sketch map: | | | 4 Well depth: 56 ft. Date of completion 122 well diameter 22 in. |
| | | | 5 A Cable tool Rotary Driven Dug |
| | - R | ρ | Hollow rod Jetted Bored Reverse rotary |
| w E | ,, | | 6 Use: Domestic Public supply Industry Irrigation Air conditioning Commercial Test well |
| <u>i</u> <u>i</u> <u>i</u> | Peri | 77> | 7 Casing: Material Step Height: above/below |
| S | - 2Y | Hima | Threaded Welded Misurface 44 in. Diam. Weight Weight Ibs./ft. |
| ⊢ → I MIIe ← | | | 12 in. to 12 ft. depth Drive shoe? Yes No |
| 2 Type and color of material | From | То | in. to ft. depth! 8 Screen: |
| Top Soil | 0 | 5 | Manufacturer Johnson Type C Steel Dia. 12 |
| Clay | _5 | 27 | Slot/gauze <u>-060</u> Length <u>12 fT</u> Set between <u>44</u> ft. and <u>56</u> ft. |
| Clay, Sandy | 27 | 30 | Fittings: Gravel pack 🛛 Yes 🗌 No Size range of material |
| Sand - Very Dirty | 30 | 42 | 9 Static water level: 22 ft. below land surface Date 8/22 |
| Sand-med-clean | 42 | 56 | 10 Pumping level below land surfaces: |
| Sand - coarse -clean | 55 | 56 | ft. after hrs. pumping g.p.m ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m. |
| Shale | 56 | | 11 Water sample submitted: |
| | | | 12 Well head completion: |
| | | | ☐ Pitless adapter ☐ Inches above grade 13 Well grouted? |
| | | | Neat cement Bentonite |
| | | | 14 Negrest source of possible contamination: |
| | | | Well disinfected upon completion? ☑ Yes □ No 15 Pump: ☑ Not installed |
| • • • • • • • • • • • • • • • • • • • • | | <u> </u> | Manufacturer's name Volts |
| | | | Length of drop pipe ft. capacity g.m.p. |
| | | | Type: ☐ Submersible ☐ Turbine |
| (use a second sheet if needed) | | | ☐ Jet ☐ Reciprocating ☐ Certrifugal ☐ Other |
| 16 Remarks: elevation Owner to instell slab, | 17 Water well contractor's certification: This well was drilled under my jurisdiction and this | | |
| 574 N- | | | report is true to the best of my knowledge and belief. |
| Topography: 8 → 7 ♥ | | | Business name / // License No. |
| ☐ Slope ☐ Upland ☑ Valley | | | Address Address Signed Julian Sed representative |
| | | | L// |

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

BR 765

Form WWC-5