

USE TYPEWRITER OR BALL POINT PEN - PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment - Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County <b>Leavenworth</b>	Fraction <b>SE 1/4 NE 1/4 NW 1/4</b>	Section number <b>3</b>	Township number <b>T 11 S</b>	Range number <b>R 21</b>	<b>(E/W)</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		<b>Mr. R. E. Spafford</b> <b>901 N. 7th</b> <b>Kansas City, Kansas 66101</b>		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>8</u> in. Completion date <u>2-22-77</u> Well depth <u>160</u> ft.				
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
5. Type and color of material			From	To	9. Casing: Material <u>PL</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>18</u> lbs./ft. Dia. <u>5</u> in. to <u>167</u> ft. depth Wall Thickness: inches or Dia. <u>   </u> in. to <u>   </u> ft. depth gage No. <u>.214</u>		
Top Soil			0	4	10. Screen: Manufacturer's name ( <u>Slotted Pipe</u> ) <u>Vinylplex, Inc.</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>06 1/16</u> Length <u>7'</u> Set between <u>35</u> ft. and <u>42</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 - 1/8</u> ft.		
Clay - Yellow			4	15	11. Static water level: <u>15</u> ft. below land surface Date <u>2-22-77</u> mo./day/yr.		
Soft Clay - Yellow			15	30	12. Pumping level below land surfaces: <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>1 1/2</u> g.p.m.		
Mud (Blue)			30	36	13. Water sample submitted: <u>   </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>   </u>		
Sand & Gravel			36	40	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> Inches above grade		
Lime - White			40	45	15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>23</u> ft.		
Sandy Shale			45	120	16. Nearest source of possible contamination: <u>Septic Tank</u> ft. <u>300</u> Direction <u>N</u> Type <u>Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sandstone - Gray			120	150	17. Pump: <u>   </u> Not installed Manufacturer's name <u>Jacuzzi</u> Model number <u>754B</u> HP <u>3/4</u> Volts <u>220</u> Length of drop pipe <u>150</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandy Shale - Blue			150	160	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>BREUER, INC.</b> <u>174</u> Business name License No. Address <u>Box 147 Basehor, Ks. 66007</u> Signed <u>[Signature]</u> Date <u>2-27-77</u> Authorized representative		
(Use a second sheet if needed)							
18. Elevation: <u>495' 8"</u>		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

11 210  
 3  
 SE NE NW  
 1/4 1/4 1/4

*BR elev = 495' 8"      11 210*