

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Leavenworth	Fraction SW 1/4 SW 1/4 - NE 1/4	Section number 32	Township number T 11 S	Range number R 21 E
2. Distance and direction from nearest town or city: 1 mile east of		3. Owner of well: Mr. William Stout		R.R. or street: Route 1 Box 125 Tonganoxie, Kansas		
Street address of well location if in city: 40 Hwy. in Reno Kansas		City, state, zip code: Route 1 Box 125 Tonganoxie, Kansas				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 3-2-76 Well depth 85 ft.		
<p>1 Mile</p>				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top Soil		0		6		9. Casing: Material PL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 18 lbs./ft. Dia. 5 in. to 85 ft. depth Wall Thickness: inches or Dia. 5 in. to 85 ft. depth gage No. 258 WT
Sandy Clay		6		18		10. Screen: Manufacturer's name Vinylplex, Inc. Type PVC Dia. 1 1/16 Slot/gauze .06 Length 80 Set between 60 ft. and 80 ft. Gravel pack? Yes Size range of material 1/4 - 1/8
Sandstone - Red		18		40		11. Static water level: 15 ft. below land surface Date 3-2-76 mo./day/yr.
Sandstone - Gray		40		85		12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield over 30 g.p.m.
						13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
						14. Well head completion: 18 inches above grade <input checked="" type="checkbox"/> Pitless adapter
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 23 ft.
						16. Nearest source of possible contamination: ft. 150 Direction South Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Not installed Manufacturer's name Jacuzzi Model number 554B HP 1/2 Volts 220 Length of drop pipe 60 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: 910		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. 174 Business name Box 147 Basehor Ks. License No. 66007 Address Basehor Ks. Signed [Signature] Date 3-17-76		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5