


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

ADD

1. Location of well:		County Leavenworth	Fraction SE_{1/4} SE_{1/4} NE_{1/4}	Section number 8	Township number T 11 S R 22	Range number 22	(E/W)
2. Distance and direction from nearest town or city: Street address of well location if in city: 5 miles east of Tonganoxie & 1/2 south				3. Owner of well: Mr. Al Gravatt R.R. or street: 7941 Waverly City, state, zip code: Kansas City, Kansas 66109			
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 8 in. Completion date 3-9-78 Well depth 125 ft.			
5. Type and color of material				From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top Soil				0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay				2	12	9. Casing: Material PL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 126 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 265	
Sandy Shale				12	48	10. Screen: Manufacturer's name (Slotted Pipe) Vinylplex, Inc. Type PVC Dia. 5" Slot/gauze 06 1/16 Length 20' Set between 73 ft. and 78 93 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8	
Sandstone				48	93	11. Static water level: 26 ft. below land surface Date 3-9-78 mo./day/yr.	
Lime				93	106	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 5 g.p.m.	
Shale				106	109	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
Lime				109	117	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade	
Shale				117	125	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.	
(Use a second sheet if needed)						16. Nearest source of possible contamination: ft. 200 Direction north Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Model number 5SLB HP 1/2 Volts 220 Length of drop pipe 115 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: 930		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. License No. 174 Business name Address Box 1147, Basaror, Ks. 66001 Signed [Signature] Date 3-9-78			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5