

54

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: LEAVENWORTH		County SE 1/4 SE 1/4 SW 1/4	Fraction 10	Section number 10	Township number FAIRMONT S	Range number R 22
2. Distance and direction from nearest town or city: 1 1/2 S. HWY 1.5 W. Street address of well location if in city: Bashor Trans.			3. Owner of well: HARDY TRENT R.R. or street: 7306 KANSAS City, state, zip code: K.C.K.			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: Machine shed 120' septic tank 170' well S MNC		6. Bore hole dia. 8 in. Completion date 6-5-77 Well depth 150 ft.		
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Surface		0		3		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
sand with clay		3		52		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 above in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 14 lbs./ft. Dia. 6 1/2 in. to 55 ft. depth Wall Thickness: inches or Dia. 4 1/2 in. to 150 ft. depth gage No. 3/16
Gravel		52		54		10. Screen: Manufacturer's name JOHNSON Type RHP Dia. 4 1/2 Slot/gauze 3/64 Length 5 ft. Set between 50 ft. and 55 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4 FINE
Sandstone (gray)		54		75		11. Static water level: mo./day/yr. 40 ft. below land surface Date 6-5-77
Lime (lt Gray)		75		97		12. Pumping level below land surfaces: 140 ft. after 15 min pumping 3 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 3 g.p.m.
Shale (dk Gray)		97		103		13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
Lime (dk Gray)		103		108		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade
Shale (lt Gray)		108		119		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Mortar <input checked="" type="checkbox"/> Bentonite _____ Concrete Depth: From 15 ft. to 30 ft.
Lime (lt Gray)		119		122		16. Nearest source of possible contamination: ft. 170 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Shale (dk)		122		127		17. Pump: Not installed Manufacturer's name Goulds Model number 10E-5 HP 3/4 Volts 230 Length of drop pipe 140 ft. capacity g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Lime (med Gray)		127		133		18. Elevation: 948 Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
Sandstone (med Gray)		133		145		19. Remarks: Customer is aware of State reg- ulation and agrees to install a 4' sq- square re-enforced concrete platform a- round top of well Hardy Trent
Shale (lt Gray)		145		150		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. A.G. GLAZE Drilling Co 350 Business name License No. Address 121 S. Chester Signed Alma G. Glaze Date 7-11-77 Authorized representative
T.D.		150		ft.		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Caved in while cementing at
15'

BR elev 894. $\nabla = 908$