

CORRECTION(S) TO WATER WELL RECORD (WWC-5)
(to rectify lacking or incorrect information)

County: Leavenworth

Location listed as:

Section-Township-Range: 2-115-22E

Fraction ($\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$): None Given

Location changed to:

2-115-22E

N2 N2

Other changes: Initial statements: _____

Changed to: _____

Comments: _____

verification method: Legal description, well owner's address,
location of city streets in that section, and
Basehor 1:24,000 topo. map. initials: DRJ date: 10/10/2005

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

White: Driller's copy
 Blue: Mail to Missouri Geological Survey
 Pink: For well owner

Bonneville Spg.
 Basehor

WATER WELL RECORD

not found 5/80
 look up in basehor phone book

not located
 83 NOT in comp file - not located

DRILLERS LOG OF WELL

Kind of rock, color, hard, or soft etc.	From (ft.)	To (ft.)
Clay	0	13
Sandstone	13	17
Lime	17	24
Shale	24	30
Lime	30	41
Shale	41	42
Slate, black	42	45
Lime	45	50
Shale	50	71
Lime	71	85
Shale	85	86
Lime	86	90
Shale	90	113
Lime	113	123
	123	T.D.

IMPORTANT DATA

Location of Well County Wyandotte
 (Show location in Section Plat) Edgewater

1/4 Sec. 2
 T. 11 S N, R. 22 E

Total depth 123' Elev. _____

Well Owner Chester Lewis
 Address Basehor, Kansas
 Mileage and direction from nearest town or highway _____

Drilling Contractor Cullum & Brown, Inc.
 Address North Kansas City, Missouri
 Date Drilled November 1, 1968

Method of Drilling rotary
 (Cable tool, rotary, reverse rotary, etc.)
 Casing Schedule 123'-4 1/2" plastic
 (Amount, Size, Setting - New, Used - Steel, Galv., - Gage or Weight)

Screen Data (if any): _____
 (Length, Diameter, Slot Size, Setting)

Measured depth to water on completed well (Static Level)
 is 15 ft. below surface
 (Land Surface, Top of Casing Etc.)
 Tested Yield 3/4 to 1 gallons per minute
 (Min., Hour)

as determined by _____
 (Bailing, Test Pumping, Etc.)
 Drawdown _____ ft. after _____ hrs.
 pumping at _____ gal. per minute

Remarks BR =
NP