


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Wyandotte	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 18	Township number T 11 S R 23 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 2 1/2 miles east of Fairmount, Kansas			3. Owner of well: Mr. Norman O'Neal R.R. or street: Box 226 City, state, zip code: Basehor, Kansas		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 8 in. Completion date 10-1-76 Well depth 175 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 78 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 175 lbs./ft. Dia. 8 in. to 175 ft. depth Wall thickness: inches or Dia. 8 in. to 175 ft. depth gage No. 258		
			10. Screen: Manufacturer's name (Slotted Pipe) Vinylator, Inc. Type PVC Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8		
Top Soil			11. Static water level: _____ mo./day/yr. 67 ft. below land surface Date 10-1-76		
Clay - Yellow			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Clay - Gray			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sandy Clay - Yellow			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
Gravel			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 5 ft.		
Sandstone - Yellow (Water)			16. Nearest source of possible contamination: ft. 100' Direction east Type septic		
Sandstone - Gray			Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Shale - Dark			17. Pump: _____ Not installed Manufacturer's name Jensen Model number 1300 HP 3/4 Volts 220 Length of drop pipe 165 ft. capacity 30 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandstone - Gray			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BRUER, INC. 174 Business name _____ License No. _____ Address Box 147 Basehor, Kas. 66008 Signed [Signature] Date 10-1-76 Authorized representative		
Shale					
Line			18. Elevation:		
Shale			19. Remarks:		
Sandy Shale			Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
Line			(Use a second sheet if needed)		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5